

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Electric Power Cable

with type designation(s)
CPCPEA/T/B 0,6/1 kV

Issued to

Conductores Monterrey, S.A. de C.V. /Viakon
SAN NICOLAS DE LOS GARZA NUEVO LEÓN, Mexico

is found to comply with

Det Norske Veritas' Rules for Classification of Ships, High Speed & Light Craft and Det Norske Veritas' Offshore Standards
IEEE 1580 (2010)
IEC 60332-3-22 (2009-02)

Application :

Control.

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Voltage class (kV) 0,6/1
Temp. class (°C) 95

This Certificate is valid until **2019-06-30**.

Issued at **Høvik** on **2015-07-27**

for **DNV GL**

DNV GL local station: **Long Beach**

Approval Engineer: **Marta Alonso Pontes**

Marit Laumann
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

Job Id: **262.1-018970-2**
Certificate No: **TAE0000078**

Product description

Type: CPCPEA/T/B 0,6/1 kV
Construction:
Conductors: Tinned stranded copper flexible
Core insulation: Type P (XLPO)
Inner sheath: Type CPE
Metal covering: Aluminium or Tinned copper or Bronze

Number of cores	Cross-section	Overall diameter Nominal
	AWG or MCM	mm
2	18	11,7
3	18	12,1
4	18	12,9
5	18	14,4
6	18	15,2
7	18	15,2
8	18	17,0
9	18	18,6
10	18	18,8
12	18	19,2
14	18	20,0
16	18	20,8
18	18	22,6
19	18	22,6
20	18	23,4
22	18	24,3
24	18	25,2
30	18	27,6
37	18	29,2
44	18	31,8
45	18	31,8
60	18	34,8
91	18	40,4
2	16	12,0
3	16	12,5
4	16	14,0
5	16	14,9
6	16	15,8
7	16	15,8
8	16	18,4
9	16	19,3
10	16	19,5
12	16	20,0
14	16	20,7
16	16	22,6
18	16	23,5
19	16	23,5
20	16	24,4
22	16	25,3
24	16	27,6
30	16	28,7

Number of cores	Cross-section	Overall diameter Nominal
	AWG or MCM	mm
37	16	30,5
44	16	33,2
45	16	33,2
60	16	36,4
91	16	43,6
2	14	12,8
3	14	14,0
4	14	14,9
5	14	15,8
6	14	16,8
7	14	16,8
8	14	19,7
9	14	20,7
10	14	21,9
12	14	22,5
14	14	23,3
16	14	24,3
18	14	25,3
19	14	25,3
20	14	27,7
22	14	28,3
24	14	29,4
30	14	31,0
37	14	32,9
44	14	36,1
45	14	36,1
60	14	39,6
91	14	47,8
2	12	14,5
3	12	15,1
4	12	16,1
5	12	17,1
6	12	19,1
7	12	19,1
8	12	22,4
9	12	23,6
10	12	23,9
12	12	24,5
14	12	25,5
16	12	27,6

Job Id: **262.1-018970-2**
Certificate No: **TAE0000078**

Number of cores	Cross-section	Overall diameter Nominal
	AWG or MCM	mm
18	12	28,7
19	12	28,7
20	12	29,8
22	12	31,1
24	12	32,3
30	12	34,1
37	12	36,3
44	12	39,9
45	12	39,9
60	12	45,5
91	12	54,6
2	10	16,3
3	10	17,0
4	10	19,0
5	10	20,3
6	10	22,7
7	10	22,7

Number of cores	Cross-section	Overall diameter Nominal
	AWG or MCM	mm
8	10	25,7
9	10	28,2
10	10	28,4
12	10	29,2
14	10	30,4
16	10	31,8
18	10	33,1
19	10	33,1
20	10	34,6
22	10	36,1
24	10	37,6
30	10	39,8
37	10	44,1
44	10	48,5
45	10	48,5
60	10	55,0
91	10	64,4

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures

Type Approval documentation

Tests carried out

Type test according to IEEE 1580-2010 and IEC 60332-22

Marking of product

Product marking: CME WIRE AND CABLE CsizePCPE⁽¹⁾ - #⁽²⁾ - 600/1000V

- (1) A or T or B, depending on the armor material
(2) # equals to number of insulated conductors

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Production Sample Tests (PST) and Routines (RT) checked (if not available tests according to PST and RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Assessment to be performed at least every second year.

END OF CERTIFICATE



Job Id: **262.1-018970-2**
Certificate No: **TAE0000078**