DNV·GL

Certificate No:
TAE000013C

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Disconnection Switch

with type designation(s)
OT 160 …. OT 400

Issued to
ABB Oy, Protection and Connection
VAASA, Finland

is found to comply with
DNV GL rules for classification – Ships and offshore units

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

This Certificate is valid until **2020-12-31**.

Issued at **Høvik** on **2016-06-17**

for **DNV GL**

DNV GL local station: **Turku**

Approval Engineer: **Nicolay Horn**

Marit Laumann
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Product description

Switch disconnectors for installation inside switchboards / enclosures onboard ships and mobile offshore units.

Type OT 160 – OT 400 as specified in the tables below.

Technical data:

Protection class:	IP20
Operational voltage, U_e	230 - 690 V
Insulation voltage, U_i	1000 V
Rated impulse vithstand voltage, Uimp	12 kV
Rated frequency:	50 - 60 Hz

	OT 160EV	OT 200E_	OT 250E_	OT 315E_	OT 400_
Rated thermal current Ith	160	200	250	315	400
Rated operational current AC-21A	160	200	250	315	400
Rated operational current AC-22A	160	200	250	315	400
Rated operational current AC-23A	160	200	250	315	400
Rated breaking capacity AC-23	1280	1600	2000	2520	3200
Rated short time withstand current Icw, 690 V 1 s.	8	8	8	15	15
Rated short time making capacity Icm	30	30	30	65	65

Application/Limitation

Switch-disconnectors for control and isolation for installation onboard ships and mobile offshore units

Type Approval documentation

Tests carried out

Type tests in accordance to IEC 60947-3 / 2008

Environmental tests (Vibration, dry heat and damp heat in accordance with DNV CN 2.4 and shock in accordance with IEC60068-2-27).

Marking of product

ABB Oy - Type designation - Rated voltage - Rated current

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type Approval is complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Production Sample Tests (PST) and Routines (RT) checked (if not available tests according to PST and RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval certificate.

Assessment to be performed at least every second year.

END OF CERTIFICATE