

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Low Voltage Cable

with type designation(s)
RU (i) S11/S105 & (c) S12/S106 250 V

Issued to

Draka Norsk Kabel - part of the Prysmian Group
DRAMMEN, Norway

is found to comply with

DNV GL rules for classification – Ships and offshore units
DNV GL class programme DNVGL-CP-0399 – Type approval – Electric cables

Application :

Instrumentation and communication.

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Voltage class (V) 250
Temp. class (°C) 90

This Certificate is valid until **2021-06-29**.

Issued at **Høvik** on **2016-10-06**

DNV GL local station: **Station Oslo Maritime and CAP**

for **DNV GL**

Approval Engineer: **Ivar Bull**

Andreas Kristoffersen
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

Product description

Type: RU (i) S11 & (c) S12 250 V

Construction:

Conductors: Tinned, stranded copper

Core insulation: EPR

Screen: Collective screen or individual screen

Outer sheath: SHF2 mud resistant according to IEC 60092-350 Annex F & Annex G.

Collective screen (c):

No of Elements:	Cross sectional area [mm ²]
2, 4, 7, 8, 12, 16, 19, 24 pairs	0,75 1,5 2,5 mm ²
2, 4, 7, 8, 12, 16, 19 , 24 triples	0,75 1,5 2,5 mm ²
1 Quad	0,75 1,5 2,5 mm ²

Individual screen (i):

No of Elements:	Cross sectional area [mm ²]
2, 4, 7, 8, 12, 16, 19, 24 pairs	0,75 1,5 2,5 mm ²
2, 4, 7, 8, 12, 16, 19 , 24 triples	0,75 1,5 2,5 mm ²
1 Quad	0,75 1,5 2,5 mm ²

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Tests carried out

Standard	Issued	General description	Limitation
IEC 60092-350	2008-02	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60092-376	2003-05	<i>Cables for control and instrumentation circuits 150/250 V (300 V)</i>	
IEC 60332-1/2	2004-07	Tests on electric and optical fibre cables under fire conditions - Part 1-2: Test for vertical flame propagation for a single insulated wire or cable	
IEC 60332-3-22	2009-02	Tests on electric and optical fibre cables under fire conditions - Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables - Category A	Bunch test Category A
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm

Job Id: **262.1-002558-9**
Certificate No: **TAE000015Y**

Standard	Issued	General description	Limitation
IEC 61034-1/2	2013-07 2013-09	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance >60%
NEK TS606 Ed5	2016	Cables for offshore installations - halogen-free low smoke flame-retardant / fire-resistant (HFFR-LS). Technical specification.	Mud resistance test: IRM903 100°C 7d. Calcium Brom. 70°C 56d. Oil based test fluid: EDC 95/11 70°C 56d

Marking of product

DRAKA NORSE KABEL or DRAKA 01 or Prysmian 01 - RU (i) or (c) - size – 150/250 V– IEC 60332-3-22 – IEC 60092-376.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Assessment to be performed at least every second year.

END OF CERTIFICATE