

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Electric Power Cable**with type designation(s)
BU P17/P110 0,6/1 kV

Issued to

**Draka Norsk Kabel - part of the Prysmian Group
DRAMMEN, Norway**

is found to comply with

DNV GL rules for classification – Ships and offshore units**DNV GL class programme DNVGL-CP-0399 – Type approval – Electric cables****Application :****General power and lighting. Control.
Fire resistant.****Product(s) approved by this certificate is/are accepted for installation on all vessels classed
by DNV GL.****Voltage class (kV) 0,6/1
Temp. class (°C) 90**This Certificate is valid until **2021-06-29**.Issued at **Høvik** on **2016-10-06**for **DNV GL**DNV GL local station: **Station Oslo Maritime and CAP**Approval Engineer: **Ivar Bull**

**Andreas Kristoffersen
Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

Job Id: **262.1-002558-9**
Certificate No: **TAE0000165**

Product description

Type: BU P17 / P110 0,6/1 kV *

Construction:

Conductors: Tinned, stranded copper and Mica-tape helically applied directly over the copper conductor

Core insulation: EPR

Outer sheath: SHF2 mud resistant according to IEC 60092-360 Annex D. NEK TS 606

* P17 are designed according to NEK TS 606 Ed 4: 2009

No of cores:	Cross sectional area [mm ²]
1	10 - 240
2, 3, 4, 7, 19, 3G, 7G	1,5
2, 3, 7, 12, 19, 3G, 4G, 5G	2,5
3, 3G, 4G	4
2, 3, 4G, 5G	6, 10
3, 4G	16
3, 3G	25
3, 4, 4G	35
3	50, 95, 150
4G	150

G = with yellow green core

Application/Limitation

This type of cable is fire resistant in accordance with IEC Publication 60331-21.

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Tests carried out

Standard	Issued	General description	Limitation
IEC 60092-350	2014-08	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-353	2011-08	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60331-1/2	2009-05	Fire resistance / Circuit integrity – Test for method for fire with shock at temperature of at least 830°C for cables rated up to and including 0,6/1 kV	90 min.

Job Id: **262.1-002558-9**
Certificate No: **TAE0000165**

Standard	Issued	General description	Limitation
IEC 60332-1-2	2004-07	Tests on electric and optical fibre cables under fire conditions - Part 1-2: Test for vertical flame propagation for a single insulated wire or cable	
IEC 60332-3-22	2009-02	Tests on electric and optical fibre cables under fire conditions - Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables - Category A	Bunch test Category A
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Determination of the amount of halogen acid gas	Low Halogen: <0,5% Halogen
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Determination of the degree of acidity of gases evolved during the combustion of materials taken from electric cables by measuring pH and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS
IEC 61034-1/2	2013-07 2013-09	Measurement of smoke density of cables burning under defined conditions - Test apparatus, procedure and requirements	Low smoke Light transmittance >60%
NEK TS606 Ed5	2016	Cables for offshore installations - halogen-free low smoke flame-retardant / fire-resistant (HFFR-LS). Technical specification.	Mud resistance test: IRM903 100°C 7d. Calcium Brom. 70°C 56d. Oil based test fluid: EDC 95/11 70°C 56d

On special request:

IEC 60331-21	1999-04	Tests for electric cables under fire conditions - Circuit integrity - Part 21: Procedures and requirements - Cables of rated voltage up to 0,6/1,0 kV	180 min. test @1000 °C
--------------	---------	--	---------------------------

Marking of product

Eg. "meter" "year" "week" DRAKA 01"part no" BU P110 - size - 0,6/1 kV - IEC 60092-353 - IEC 60331-1/2 - IEC 60332-3-22 "Prod. order no".

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Assessment to be performed at least every second year.

END OF CERTIFICATE