

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Electric Power Cable

with type designation(s)
BFOU[P105], BFOU(C), BFCU, BFCU(C), BFOU-EMC

Issued to

Kukdong Electric Wire Co., Ltd.
Jincheon-gun Chungcheongbuk-do, Korea

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft
IEC 60092-353 (2016-09)

Application :

General power and lighting. Control. Fire resistant. Flame retardant Cat.A. Halogen free. Low smoke. Mud resistant. Cold bending (-40°C) Cold impact (-35°C)

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Rated voltage (kV) 0.6/1
Temp. class (°C) 90

Issued at **Busan** on **2018-03-08**

This Certificate is valid until **2023-03-07**.

DNV GL local station: **Seoul**

for **DNV GL**

Approval Engineer: **Eun Jin Lee**

.....
Michael Jost Auf der Stroth
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

Type : BFOU[P105], BFOU(C), BFCU, BFCU(C), BFOU-EMC

Conductors: Tinned stranded copper
Insulation: EPR + Mica tape
Inner covering: Halogen free compound
Collective screen: Cu/PS tape w/drain wire('C') type only
Metal covering: Galv. Steel wire braid(except single core cable, 'C') or
Tinned copper wire braid(O)
Cu/PS tape & Copper wire braid(-EMC only)
Outer sheath: SHF2

Number of cores	Conductor cross-section (mm ²)
1C, 2C, 3C, 4C, 2C+E, 3C+E, 4C+E	1.0 ~ 150
5~44C	1.0, 1.5, 2.5
For BFOU-EMC : 3C, 3C+E, 3C+3E	2.5 ~ 150 2.5 ~ 10 16 ~ 150

Application/Limitation

This type of cable is fire resistant in accordance with IEC Publication 60331.

The requirements of SOLAS Chapter II-1 Part D Reg. 45.5.2 to limit Fire Propagation along Bunches of Cables or Wires are fulfilled without any additional measures.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
IEC 60092-353	2016-09	Power cables for rated voltages 1kV and 3kV	
IEC 60092-360	2014-04	Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation, telecommunication cables	
IEC 60332-1	2015-07	Test for vertical flame propagation for a single insulated wire or cable	
IEC 60331-21	1999-04	Tests for electric cables under fire conditions – Circuit integrity – Part 21: Procedures and requirements – Cables of rated voltage up to 0,6/1,0 kV	@ 750°C/120 min.
IEC 60331-1/-2	2009-05	Fire resistance / Circuit integrity – Test method for fire <i>with shock</i> at temperature of at least 830°C for cables rated up to and including 0,6/1 kV	@ 830°C w/shock (120 min)
IEC 60332-3-22	2009-02	Flame retardance in bunch	Cat. A
IEC 60684-2	2011-08	Flexible insulating sleeving – Part 2: Methods of test.	Fluorine content <0.1%
IEC 60754-1/2	2011-11	Determination of the amount of halogen acid gas/ Determination of degree of acidity of gases evolved during the combustion of materials taken from electric cables by	Low Halogen <0,5% Halogen free ≥4,3pH, ≤10μS/mm

Job Id: **262.1-022966-1**
Certificate No: **TAE00001GF**

Standard	Release	General description	Limitation
		measuring pH and conductivity	
IEC 61034-1/-2	2005-04	Measurement of smoke density of cables during under conditions	Low smoke >60%
NEK 606	2016	Cables for offshore installations – Technical specification	Oil & Mud resistant – Category a/b/c/d
CSA C22.2 No. 03	2009	5.11 Flexibility at any specified temperature	Cold bend(-40°C)
CSA C22.2 No. 03	2009	5.12 Abnormal low temperature – impact	Cold impact(-35°C)
UL1581	2015	UV resistance	

Marking of product

0.6/1 kV – Type designation – Size – IEC 60331(120) – IEC 60332 Cat. A - KUKDONG – Year of manufacture - Length

Periodical assessment

The scope of the retention/renewal survey is to verify that the conditions stipulated for the Type Approval Certificate are complied with and that no alterations are made to the design and/or the material of product.

The main elements of the survey are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Check of results from Production Sample Tests (PST) and Routine tests (RT) (if not available, PST and RT are to be carried out)
- Review of type approval documentation
- Review of possible changes in design, material and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE