

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Contactor

with type designation(s)
DC operated AL contactors

Issued to

ABB France
CHASSIEU Cedex, France

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

For installations inside switchboards / enclosures onboard ships and offshore units

Rated Voltage (V) 690
Rated Current (A) 22- 60 (AC 1/690V)
Frequency (Hz) 50 - 60

Issued at **Høvik** on **2017-04-17**

This Certificate is valid until **2021-12-04**.

DNV GL local station: **Marseille**

for **DNV GL**

Approval Engineer: **Nicolay Horn**

.....
Andreas Kristoffersen
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Name and place of manufacturer

ABB France, Chassieu, France	ABB Bulgaria Branch Rakovski Plovdiv, Bulgaria
---------------------------------	---

Product description

Low voltage DC contactors

Technical data:

Contactor type		AL9-30			AL12-30		
Number of poles		3			3		
Rated insulation voltage (U _i)	V	1000			1000		
Rated impulse withstand voltage	kV	8			8		
Rated Frequency	Hz	50/60			50/60		
Degree of protection	IP	20			20		
Rated thermal current (I _{th})	A	16			16		
Utilization category		AC3		AC1	AC3		AC1
Ambient temperature	°C	55		40 55	55		40 55
Rated operational voltage (U _e)	U	400	690	690	400	690	690
Rated operational current (I _e)	I	9	7	25 22	12	9	27 25
Rated power	kW	4		- -	5.5		- -

Contactor type		AL16-30			AL26-30		
Number of poles		3			3		
Rated insulation voltage (U _i)	V	1000			1000		
Rated impulse withstand voltage	kV	8			8		
Rated Frequency	Hz	50/60			50/60		
Degree of protection	IP	20			20		
Rated thermal current (I _{th})	A	16			16		
Utilization category		AC3		AC1	AC3		AC1
Ambient temperature	°C	55		40 55	40		40 55
Rated operational voltage (U _e)	U	400	690	690	400	690	690
Rated operational current (I _e)	I	17	10	30 27	26	17	45 40
Rated power	kW	7.5		- -	11		- -

Contactor type		AL26-40			AL30-30		
Number of poles		4			3		
Rated insulation voltage (U _i)	V	1000			1000		
Rated impulse withstand voltage	kV	8			8		
Rated Frequency	Hz	50/60			50/60		
Degree of protection	IP	20			20		
Rated thermal current (I _{th})	A	16			16		
Utilization category		AC3		AC1	AC3		AC1
Ambient temperature	°C	55		40 55	55		40 55
Rated operational voltage (U _e)	U	400	690	690	400	690	690
Rated operational current (I _e)	I	26	17	45 40	32	21	55 55
Rated power	kW	11		- -	15		- -

Contactor type		AL40-30		
Number of poles		3		
Rated insulation voltage (U _i)	V	1000		
Rated impulse withstand voltage	kV	8		

Job Id: **262.1-024554-1**
Certificate No: **TAE00001UN**

Rated Frequency	Hz	50/60		
Degree of protection	IP	20		
Rated thermal current (I_{th})	A	16		
Utilization category		AC3	AC1	
Ambient temperature	°C	55	40	55
Rated operational voltage (U_e)	U	400	690	690
Rated operational current (I_e)	I	37	25	60
Rated power	kW	18.5	-	-

Technical data auxiliary contacts:

Add-on Auxiliary contacts w/ screw terminals	1-pole CA 5-xy, 4-pole CA
Rated control circuit voltage	690 V
Rated impulse withstand voltage U_{imp}	6 kV
Conventional thermal current I_{th}	16 A
Rated operational current (I_e) (AC-15 690 V)	2 A
Rated operational current (I_e) (DC-13 250 V)	0.3 A
Short circuit protection (gG fuse)	10 A

x=N.O. contact y= N.C. contact

Application /limitation

No add-on auxiliary contacts on AL40-30 permitted.

Environmental classes:

Temperature: B, Humidity : B, Vibration : C.

Type Approval documentation

Tests carried out

Guidelines for Performance of Type Approvals Part 2, Edition 2003.

Type tests according to IEC 60947-1 (2001-12), IEC 60947-4-1(2002-12) and IEC60947-5-1 (2003-11).

Marking of product

ABB – Type designation – Rated voltage – Breaking capacity.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval is complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from d Routines (RT) checked (if not available tests RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate

Periodical assessment to be performed at 2 and 3.5 years and at renewal.

END OF CERTIFICATE