

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Low Voltage Cable**

with type designation(s)
CHJ86/SC & CHJP86/SC 150 / 250 V

Issued to

Changzhou Marine Cable Co., Ltd. (CMC)
CHANGZHOU JIANGSU, China

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :**Control and instrumentation.**

Products approved by this certificate are accepted for installation on all vessels classed by DNV GL.

Rated voltage (V) 150 / 250 V

Temp. class (°C) 90

Issued at **Høvik** on **2017-11-06**

This Certificate is valid until **2022-06-30**.

DNV GL local station: **Nanjing**

for **DNV GL**

Approval Engineer: **Marta Alonso Pontes**

.....
Andreas Kristoffersen
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

Type: CHJ86/SC & CHJP86/SC 150/250 V

Construction:

Conductors: Tinned or plain, stranded copper
Core insulation: XLPE
Individual screen: Tinned copper wire braid or taped screen (CHJP86/SC only)
Inner covering: Tape
Screen: Copper wire braid
Outer sheath: SHF1

Number of Pairs	Conductor cross section [mm ²]
1, 2, 3, 4, 5, 7, 8, 10, 12, 14, 16, 19, 24	0.5, 0.75, 1, 1.5

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
IEC 60092-376	2003-05	Cables for control and instrumentation circuits 150/250 V (300 V)	
IEC 60332-3-22	2009-02	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 61034-1/2	2013-07 2013-09	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance ≥60%

Marking of product

CMCW – CHJ86/SC or CHJP86/SC – 150/250 V – size – IEC 60332-3-22 – Lot No.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.



Job Id: **262.1-007592-4**
Certificate No: **TAE0000240**

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE