

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Low Voltage Cable**

with type designation(s)

S3 & S3/S7 BFOU (i) & S4 & S4/S8 BFOU (c) 150 / 250 V

Issued to

Changzhou Marine Cable Co., Ltd. (CMC)
CHANGZHOU JIANGSU, China

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Control. Instrumentation and communication.****Products approved by this certificate are accepted for installation on all vessels classed by DNV GL.****Rated voltage (V) 150 / 250 V****Temp. class (°C) 90**Issued at **Høvik** on **2017-11-06**This Certificate is valid until **2022-06-30**.for **DNV GL**DNV GL local station: **Shanghai**Approval Engineer: **Marta Alonso Pontes**

Andreas Kristoffersen
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

Type: S3 & S3/S7 BFOU(i) & S4 & S4/S8 BFOU(c) 150/250 V
Conductors: Tinned stranded copper class 2
Core insulation: Mica tape + EPR
(i): Individual screen
(c): Collective screen
Inner covering: Halogen free compound
Metal covering: Tinned copper wire braid
Outer sheath: SHF2 or SHF Mud

Number of Pairs	Conductor cross section [mm ²]
1, 2, 3, 4, 5, 7, 8, 10, 12, 14, 16, 19, 24	0.75, 1, 1.5

Number of Triads	Conductor cross section [mm ²]
1, 2, 4, 8, 10, 12, 16, 24	0.75, 1, 1.5

Application/Limitation

This type of cable is fire resistant in accordance with IEC Publication 60331.

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
IEC 60092-376	2003-05	Cables for control and instrumentation circuits 150/250 V (300 V)	
IEC 60332-3-22	2009-02	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60331-1	2009-05	Fire resistance / Circuit integrity – Test for method for fire <i>with shock</i> at temperature of at least 830°C for cables rated up to and including 0,6/1 kV and with an overall diameter exceeding 20 mm	90 min
IEC 60331-21	1999-04	Fire resistance / Circuit integrity -Tests for electric cables under fire conditions for Cables of rated voltage up to and including 0,6/1,0 kV and with an overall diameter under 20 mm	90 min
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 61034-1/2	2013-07 2013-09	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance ≥60%

Job Id: **262.1-007592-4**
Certificate No: **TAE000024B**

Standard	Release	General description	Limitation
NEK 606 Ed.4	2009-05	Cables for offshore installations. Halogenfree and/or mud resistant. Technical specification.	Mud resistance test: IRM903 100°C 7d. Calcium Bromide 70°C 56d. Oil based mud: Carbo Sea 70°C 56d or EDC 95/11 70°C 56d

Marking of product

S3 or S3/S7 BFOU(i) or S4 or S4/S8 BFOU(c)– 150/250 V – size – IEC 60331-1 or IEC 60331-21 – IEC 60332-3-22 – Lot No.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE