

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Electric Power Cable**with type designation(s)
P108 UX H-M 0,6/1 kV

Issued to

Controlcavi Industria S.r.l.
FERENTINO, Italy

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Earth conductor.****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Rated voltage (kV) 0,6/1****Temp. class (°C) 90**Issued at **Høvik** on **2017-09-26**This Certificate is valid until **2022-06-30**.for **DNV GL**DNV GL local station: **Milan**Approval Engineer: **Ivar Bull**

Andreas Kristoffersen
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Job Id: **262.1-010304-3**
Certificate No: **TAE000025D**

Product description

Type: P108 UX H-M 0,6/1 kV to be used as yellow/green earth conductor

Construction:

Conductor: Tinned, flexible copper class 2 or class 5
Core insulation: SHF2 H-M (Oils & Muds resistant)
Tested with Total AZOLLA 68 hydraulic oil.

No of cores:	Cross sectional area [mm ²]
1	6 - 300

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Only to be used as yellow/green earth conductor.

Type Approval documentation

Tests carried out

	Release	General description	Limitation
DNVGL-CP-0399	2016-03	Class Programme Electric cables	
IEC 60092-350	2014-08	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	Including: Ozone resistance
IEC 60092-353	2016-09	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	
IEC 60332-1-2	2015-07	Tests on electric cables under fire conditions. Test for vertical flame propagation for a single insulated wire or cable.	
IEC 60332-3-22	2009-02	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Bunch test Category A
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 60684-2	2011-08	Flexible insulating sleeving – Part 2: Methods of test.	Fluorine content < 0,1%
IEC 61034-1/2	2013-07 2013-09	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance ≥60%

Job Id: **262.1-010304-3**
Certificate No: **TAE000025D**

	Release	General description	Limitation
DNVGL-CP-0399	2016-03	Class Programme Electric cables	
CSA C22.2 No. 38.05	2007-03	Thermoset Insulated Wires and cables. Cold bending & impact tests	Cold bend: -40°C Cold impact: -40°C
CSA C22.2 No. 0.3-01	2005-01	Test Methods	
NEK 606 Ed. 5	2016	Cables for offshore installations halogen-free, low smoke, flame retardant/fire resistant. Technical specification.	
UL 1581	2013-01	Reference Standard for Electrical Wires, Cables, and Flexible Cords. Paragraph 1200.1: Sunlight resistance Carbon arc and Xenon arc test.	720h. Max tensile strength and elongation@break decay 20%.

Marking of product

CCI – P108 UX H-M – Size – 0,6/1 kV – IEC 60092-353 – NEK 606 – IEC 60332-3-22 Cat.A – Year – Metre mark – QA No.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine tests (RT) and selected type tests (ref. to applicable class programs) checked (if not available these tests shall be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE