

TYPE APPROVAL CERTIFICATE

This is to certify:**That the High Voltage Cable**

with type designation(s)

CEF/DA&SA, CEH/DA&SA, CEV/DA&SA 3,6/6 kV, CEF/DA&SA, CEH/DA&SA, CEV/DA&SA 6/10 kV, CEF/DA&SA, CEH/DA&SA, CEV/DA&SA 8,7/15 kV

Issued to

**Hebei Huatong Wires & Cables Group Co., Ltd.
Tangshan, China**

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****General power.****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.**

Type	Rated voltage (kV)	Temp. class (°C)
CEF/DA&SA, CEH/DA&SA, CEV/DA&SA 3,6/6 kV	3,6/6	90
CEF/DA&SA, CEH/DA&SA, CEV/DA&SA 6/10 kV	6/10	90
CEF/DA&SA, CEH/DA&SA, CEV/DA&SA 8,7/15 kV	8,7/15	90

Issued at **Hamburg** on **2017-08-10**This Certificate is valid until **2022-08-09**.for **DNV GL**DNV GL local station: **Tianjin**Approval Engineer: **Carsten Hunsalz**

.....
Duy Nam Le
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

Type: CEF/DA&SA, CEH/DA&SA and CEV/DA&SA 3,6/6 kV, 6/10 kV and 8,7/15kV

Construction:

Conductors: Metal coated, stranded copper
Core insulation: Semi-conducting compound, EPR , Semi-conducting compound, Copper tape layer
Outer sheath: SE1 (CEF) SH (CEH) ST2 (CEV)

Number of cores x conductor cross-section	Overall Dia- meter min.	Overall Dia- meter max.
mm ²	mm	mm
CEF/DA&SA CEH/DA&SA CEV/DA&SA 3,6/6 kV		
1 x 10	16,0	21,5
1 x 16	17,0	23,0
1 x 25	18,5	24,0
1 x 35	19,5	25,5
1 x 50	21,0	27,0
1 x 70	22,5	29,0
1 x 95	24,0	31,0
1 x 120	26,0	33,0
1 x 150	27,0	34,5
1 x 185	29,0	37,0
1 x 240	31,5	39,5
1 x 300	34,0	42,5
1 x 400	37,0	46,0
1 x 500	40,5	50,0
1 x 630	45,0	55,0
3 x 10	33,5	42,0
3 x 16	36,0	44,5
3 x 25	38,5	48,0
3 x 35	41,0	50,5
3 x 50	43,5	54,0
3 x 70	47,0	58,5
3 x 95	51,0	63,5
3 x 120	54,5	67,0
3 x 150	57,5	70,5

Number of cores x conductor cross- section	Overall Dia- meter min.	Overall Dia- meter max.
mm ²	mm	mm
CEF/DA&SA CEH/DA&SA CEV/DA&SA 6/10 kV		
1 x 16	18,0	23,5
1 x 25	19,0	25,0
1 x 35	20,5	26,5
1 x 50	21,5	28,0
1 x 70	23,5	30,0
1 x 95	25,0	32,0
1 x 120	26,5	34,0
1 x 150	28,0	35,5
1 x 185	30,0	37,5
1 x 240	32,5	40,5
1 x 300	34,5	43,0
1 x 400	38,0	47,0
1 x 500	41,0	50,5
1 x 630	45,5	56,5
3 x 16	37,5	46,5
3 x 25	40,5	50,0
3 x 35	42,5	53,0
3 x 50	45,0	56,0
3 x 70	49,0	60,5
3 x 95	53,0	65,5
3 x 120	56,5	69,0
3 x 150	59,5	72,5

Number of cores x conductor cross-section	Overall Dia- meter min.	Overall Dia- meter max.
mm ²	mm	mm
CEF/DA&SA CEH/DA&SA CEV/DA&SA 8,7/15 kV		
1 x 25	21,5	27,5
1 x 35	22,5	29,0
1 x 50	24,0	30,5
1 x 70	25,5	32,5
1 x 95	27,5	34,5

Number of cores x conductor cross- section	Overall Dia- meter min.	Overall Dia- meter max.
mm ²	mm	mm
CEF/DA&SA CEH/DA&SA CEV/DA&SA 8,7/15 kV		
3 x 25	45,5	55,5
3 x 35	48,5	58,5
3 x 50	50,5	61,5
3 x 70	54,5	66,0
3 x 95	58,0	70,5

Job Id: **262.1-008108-14**
Certificate No: **TAE000026D**

1 x 120	29,0	36,5
1 x 150	30,5	38,0
1 x 185	32,0	40,0
1 x 240	34,5	43,0
1 x 300	37,0	45,5
1 x 400	40,0	49,5
1 x 500	43,0	53,0
1 x 630	47,5	58,5

3 x 120	61,5	74,5
3 x 150	65,0	78,0

Application/Limitation

General power.

The following applies to SA type cables only:

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
IEC 60092-350	2014-08	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-354	2014-08	Electrical installations in ships - Part 354: Single- and three-core power cables with extruded solid insulation for rated voltages 6 kV (Um = 7,2 kV) up to 30 kV (Um = 36 kV)	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60332-3-22*	2009-02	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.

*SA type only

Marking of product

Hebei Huatong Wires & Cables Group Co.,Ltd. – CEF/DA or CEF/SA or CEH/DA or CEH/SA or CEV/DA or CEV/SA - size – 3,6/6 kV or 6/10 kV or 8,7/15kV – IEC 60332-3-22* – Lot no.

*SA type only

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

Job Id: **262.1-008108-14**
Certificate No: **TAE000026D**

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE