

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Lightweight Electric Cable**

with type designation(s)

CL105F-SO 0,6/1 kV, CL105F-PO & -TO & -PIO & -TIO 150/250 V

Issued to

**Tyco Electronics UK Ltd
Swindon, United Kingdom**

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Fire resistant for general power and lighting. Control. Instrumentation and communication.
Product(s) approved by this certificate is/are accepted for installation on all vessels classed
by DNV GL.**

Type	Rated voltage (kV)	Temp. class (°C)
CL105F-SO 0,6/1 kV	0,6/1	90
CL105F-PO & -TO & -PIO & -TIO 150/250 V	150/250 V	90

Issued at **Høvik** on **2018-01-01**This Certificate is valid until **2022-12-31**.for **DNV GL**DNV GL local station: **London**Approval Engineer: **Ivar Bull**

.....
Andreas Kristoffersen
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

CL105F-SO 0,6/1 kV and
CL105-PO & -TO & -PIO -& -TIO 150/250 V

Conductors:	Tinned, stranded copper
Core insulation:	Mica tape + Halogen-Free Flame Retarded Thermoplastic compound
Individual screen (I) (if any)	Aluminium polyester tape
Metal covering (O):	Tinned copper wire braid
Outer sheath:	SHF2

CL105F-SO 0,6/1 kV

No of elements:	Cross sectional area [mm ²]
2, 3, 4, 5, 7, 10, 12, 14, 19, 24, 27, 37 cores	1,0 1,5 2,5
2, 3, 4, 5 cores	4, 6, 10,

CL105-PO & -TO & -PIO -& -TIO 150/250 V

No of elements:	Cross sectional area [mm ²]
1, 2, 3, 4, 7, 8, 10, 12, 14, 15, 16, 19, 24, 27, 32, 37 pairs	0,50 0,75 1,0 1,5 2,5
1, 2, 3, 4, 7, 8, 10, 12, 15, 16, 19, 24, 32 triples	0,50 0,75 1,0 1,5 2,5

Application/Limitation

This type of cable is fire resistant in accordance with IEC Publications 60331-1/2.

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Tests carried out

	Release	General description	Limitation
DNVGL-CP-0400	2015-12	Class Programme Lightweight electric cables	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60331-1/2	2009-05	Fire resistance / Circuit integrity – Test for method for fire with shock at temperature of at least 830°C for cables rated up to and including 0,6/1 kV	Minimum 120 min+15 min cooling down time
IEC 60332-3-22	2009-02	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Bunch test Category A
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm

Job Id: **262.1-015897-6**
Certificate No: **TAE00002CE**

IEC 61034-1/2	2013-07 2013-09	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance $\geq 60\%$
---------------	--------------------	--	---

Marking of product

Tyco Electronics – CL105F-SO – size - 0,6/1 kV – IEC 60331-1/2 – IEC 60332-3-22 – Lot No or

Tyco Electronics – CL105F-PO or TO or PIO or TIO - size – 150/250 V – IEC 60331-1/2 – IEC 60332-3-22 – Lot No.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine tests (RT) and selected type tests (ref. to applicable class programs) checked (if not available these tests shall be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE