

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Electric Power Cable**

with type designation(s)
MGH-FFR 0,6/1 kV

Issued to

Untel Kablolari San. ve Tic. A.S.
Dilovasi, Turkey

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft
DNV GL class programme DNVGL-CP-0399 – Type approval – Electric cables

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Rated voltage (kV) 0,6/1
Temp. class (°C) 90

Issued at **Høvik** on **2018-02-23**

This Certificate is valid until **2023-02-22**.

DNV GL local station: **Istanbul**

for **DNV GL**

Approval Engineer: **Georgy Abramenko**

.....
Andreas Kristoffersen
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Job Id: **262.1-027537-1**
Certificate No: **TAE00002NS**

Product description

Type: MGH-FFR 0,6/1 kV

Conductors: Plain or tinned, stranded copper class 2 or class 5

Core insulation: Mica tape + HEPR

Inner covering: Extruded rubber compound

Outer sheath: SHF1

Numbers of cores	Conductor cross sections
1 2 3 4	1 1,5 2,5 4 6 10 16 25 35 50 70
1 3 4	95 120
1	150 185 240 300 400 500
5 7	1 1,5 2,5 4
10 12 14 16 19 24	1 1,5 2,5

Application/Limitation

This type of cable is fire resistant in accordance with IEC Publication 60331.

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bundles of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
IEC 60092-350	2014-08	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-353	2016-09	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	
IEC 60331-21	1999-04	Tests for electric cables under fire conditions - Circuit integrity - Part 21: Procedures and requirements - Cables of rated voltage up to and including 0,6/1,0 kV	Minimum 90 min + 15 min cooling down time
IEC 60332-3-22	2009-02	Tests on electric and optical fibre cables under fire conditions - Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables - Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 61034-1/2	2005-04	Measurement of smoke density of cables burning under defined conditions - Test apparatus, procedure and requirements	Low smoke Light transmittance ≥60%

Marking of product

ÜNTEL - MGH-FFR - size - 0,6/1 kV - IEC 60331-21 - IEC 60332-3-22 - Lot No

Periodical assessment



Job Id: **262.1-027537-1**
Certificate No: **TAE00002NS**

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE