

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Low Voltage Cable**with type designation(s)
ÖLFLEX® CLASSIC 135 CH

Issued to

**U.I. Lapp GmbH
Stuttgart, Germany**

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Rated voltage (V) 300/500****Temp. class (°C) 75**Issued at **Hamburg** on **2018-02-21**This Certificate is valid until **2020-07-03**.for **DNV GL**DNV GL local station: **Augsburg**Approval Engineer: **Carsten Hunsalz**

**Arne Schaarmann
Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

Halogen free, flame retardant power and control cables

Rated voltage: U₀/U 300/500 V
Temperature range: -40 °C to +75 °C fixed installation (20.000 h)
Conductor: Flexible stranded copper class 5
Insulation: Polyolefin based TI6
Screen: Tinned copper wire 85% coverage rate
Outer sheath: Halogen free TM7

Number of cores: Cross-sectional areas:

2 to 25	0,5 + 0,75 + 1 + 1,5 mm ²
2 to 12	2,5 mm ²
3 to 7	4 + 6 mm ²
4 to 7	10 mm ²
4 to 5	16 + 25 mm ²
4	35 mm ²

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Power and Control.
Flame retardant Cat. A. Halogen free. Low smoke.

Type Approval documentation

Test report: LAPP Forbach No.124.15+086.15 dated 22-Mai-15 + 07-Mai-15
LAPP Forbach No. 154.15 dated 2-July-15
VDE 562800-9020-0001/97313 a-c dated 2008-10-01
VDE 562800-9020-0001/97313 d-f dated 2008-10-01
Data sheet: DB1123000gl and DB1123200gl

Tests carried out

Standard	Release	General description	Limitation
UL AWM 785 Style		10701 + 21217	
EN 50525-3-11	2011-05	Electric cables -Low voltage energy cables of rated voltages up to and including 450/750 V (U ₀ /U) - Part 3-11: Cables with special fire performance - Flexible cables with halogen-free thermoplastic insulation, and low emission of smoke	
EN 50363-7	2005-11	Insulating, sheathing and covering materials for low voltage energy cables Part 7: Halogen-free, thermoplastic insulating compounds	
EN 50363-8	2005-11	Insulating, sheathing and covering materials for low voltage energy cables Part 8: Halogen-free, thermoplastic sheathing compounds	
IEC 60228	2004-11	Conductors of insulated cables	

Job Id: **262.1-028283-1**
Certificate No: **TAE00002RK**

Standard	Release	General description	Limitation
IEC 60332-1-2	2015-07	Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable –Procedure for 1 kW pre-mixed flame	
IEC 60332-3-22 IEC 60332-3-24 IEC 60332-3-25	2009-02	Tests on electric cables under fire conditions - Part 3-22/24/25: Test for vertical flame spread of vertically-mounted bunched wires or cables - Category A/C/D	Bunch test Category A/C/D.
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 61034-1/2	2013-07 2013-09	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance >60%

Marking of product

LAPP KABEL **STUTTGART** * ÖLFLEX® CLASSIC 135 CH * size * 300/500 V

Place of production

Cableries LAPP S.A.R.L. / Forbach in France

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE