DNV·GL

Certificate No:
TAE00002X9

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Electric Power Cable

with type designation(s)
RXZ-HF EMC 0,6/1kV, RXZ-HF VFD EMC 1,8/3kV, RXZ-HF VFD EMC 3G 1,8/3kV, RXZ-HF VFD EMC Soft 1,8/3kV

Issued to
amo specialkabel AB
ALSTERMO, Sweden

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

General power and lighting. VFD version for variable frequency drives.

Products approved by this certificate are accepted for installation on all vessels classed by DNV GL.

Type	Rated voltage (kV)	Temp. class (°C)
RXZ-HF EMC 0,6/1kV	0,6/1	90
RXZ-HF VFD EMC 1,8/3kV	1,8/3kV	90
RXZ-HF VFD EMC 3G 1,8/3kV	1,8/3kV	90
RXZ-HF VFD EMC Soft 1,8/3kV	1,8/3kV	90

Issued at **Høvik** on **2018-05-30**
This Certificate is valid until **2023-05-29**.
DNV GL local station: **Malmö**

Approval Engineer: **Ivar Bull**

for **DNV GL**

Andreas Kristoffersen
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Product description

Types: RXZ-HF EMC 0,6/1kV,
RXZ-HF VFD EMC 1,8/3kV,
RXZ-HF VFD EMC 3G 1,8/3kV
RXZ-HF VFD EMC Soft 1,8/3kV

Construction:

Conductors:	Plain/tinned, stranded copper class 2 or class 5
Core insulation:	HF XLPE
Filler:	Flame retardant halogen-free compound
Inner covering	Lapped or extruded
Screen (if any):	Metal backed PE tape
Metal covering:	Plain/tinned copper wire braid or galvanised steel wire braid
Outer sheath:	SHF 1

RXZ-HF EMC 0,6/1kV:

No of cores:	Cross sectional area [mm2]
1	1,5 - 300
2	1,5 - 95
3	1,5 - 240
4	1,5 - 95
5	1,5 - 25
6, 7, 10, 12, 14, 16, 19, 24, 25, 27, 37	1,5
7, 9, 10, 14, 16, 19, 24, 27, 37	2,5

RXZ-HF VFD EMC 1,8/3kV:

No of cores:	Cross sectional area [mm2]
3	16 -240
4	95

RXZ-HF VFD EMC 3G 1,8/3kV:

No of cores:	Cross sectional area [mm2]
3/3E	16/2,5 – 240/50

RXZ-HF VFD EMC Soft 1,8/3kV:

No of cores:	Cross sectional area [mm2]
3	120

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Job Id: **262.1-012026-6**
Certificate No: **TAE00002X9**

Tests carried out

	Release	General description	Limitation
DNVGL-CP-0399	2016-03	Class Programme Electric cables	
IEC 60092-350	2014-08	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60092-353	2016-09	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	
IEC 60332-3-22	2009-02	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 61034-1/2	2013-07 2013-09	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance ≥60%

Marking of product

AMOKABEL RXZ EMC – size – IEC 60092-353- IEC 60332-3-22 - DNVGL 0,6/1kV - YYWW or
AMOKABEL RXZ VFD EMC – size – IEC 60092-353 - IEC 60332-3-22 -DNVGL - 1,8/3kV – YYWW or
AMOKABEL RXZ VFD EMC 3G –size – IEC 60092-353 - IEC 60332-3-22 - DNV 1,8/3kV - YYWW or
AMOKABEL RXZ VFD EMC Soft – size – IEC 60092-353 - IEC 60332-3-22 -DNVGL 1,8/3kV - YYWW

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine tests (RT) and selected type tests (ref. to applicable class programs) checked (if not available these tests shall be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE