

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Electric Power Cable**

with type designation(s)

**DFA (IEEE1580),
DFC (IEEE 1580),
DFM (IEEE 1580)**

Issued to

**TriCab (USA) Inc.
Worcester, MA, USA**

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****General power and lighting****Products approved by this certificate are accepted for installation on all vessels classed by DNV GL.**

Type	Rated voltage (kV)	Temp. class (°C)
DFA (IEEE1580)	0,6/1	90
DFC (IEEE 1580)	0,6/1	90
DFM (IEEE 1580)	0,6/1	90

Issued at **Høvik** on **2019-01-23**This Certificate is valid until **2023-06-30**.for **DNV GL**DNV GL local station: **New York**Approval Engineer: **Ivar Bull**

.....

Marta Alonso Pontes
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Job Id: **262.1-009092-5**
Certificate No: **TAE000031X**

Product description

Type: DFA (IEEE1580),
DFC (IEEE 1580),
DFM (IEEE 1580)

Construction:
Conductors: Tinned stranded copper, Class 5
Core insulation: LSX
Inner covering: Polypropylene tape
Screen: Tinned copper wire braid with Aluminium laminate tape under braid
Outer sheath: TPO for DFA, SHF-2 for DFC, SHF-2 MUD for DFM

Number of conductors x cross sectional area mm ²
3 x 10 + 3 x 1,5 E
3 x 16 + 3 x 2,5E
3 x 25 + 3 x 4E
3 x 35 + 3 x 6E
3 x 50 + 3 x 10E
3 x 70 + 3 x 10E
3 x 95 + 3 x 16E
3 x 120 + 3 x 16E
3 x 150 + 3 x 25E
3 x 185 + 3 x 25E
3 x 240 + 3 x 35E
3 x 300 + 3 x 50E
3 x 400 + 3 x 50E
3 x 500 + 3 x 70E

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
DNVGL-CP-0399	2016-03	Class Programme Electric cables	
IEEE1580	2010	IEEE Recommended Practice for Marine Cable for Use on Shipboard and Fixed or Floating Facilities	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	For SHF2 MUD sheath
IEC 60332-3-22	2009-02	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Bunch test Category A
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen

Job Id: **262.1-009092-5**
Certificate No: **TAE000031X**

Standard	Release	General description	Limitation
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 61034-1/2	2013-07 2013-09	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance ≥60%
NEK TS 606 Ed5	2016	Cables for offshore installations. Halogen-free and/or mud resistant. Technical specification.	Mud resistance test: IRM903 100°C 7d. Calcium Bromide 70°C 56d. Oil based mud: EDC 95/11 70°C 56d or CarboSea 70°C 56d

Marking of product

TRICAB (USA) – DFA or DFC or DFM – size – 0,6/1 kV – IEEE1580 - IEC 60332-3-22 – Lot No.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine tests (RT) and selected type tests (ref. to applicable class programs) checked (if not available these tests shall be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE