

# TYPE APPROVAL CERTIFICATE

**This is to certify:****That the Low Voltage Cable**with type designation(s)  
**PRYSMIAN - Navy Cable FMSGSGO**

Issued to

**Prysmian Kabel und Systeme GmbH**  
**Neustadt b. Coburg, Bayern, Germany**

is found to comply with

**DNV GL rules for classification – Ships, offshore units, and high speed and light craft****Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Rated voltage (V) 250****Temp. class (°C) 90**Issued at **Hamburg** on **2018-10-11**This Certificate is valid until **2023-10-10**.for **DNV GL**DNV GL local station: **Augsburg**Approval Engineer: **Carsten Hunsalz**

---

**Arne Schaarmann**  
**Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Job Id: **262.1-028178-1**  
Certificate No: **TAE000036B**

## Product description

EPR insulated and elastomer sheathed telecommunication cables, screened

Type PRYSMIAN – Navy Cable FMSGSGO

Rated voltage: 250 V  
Maximum operating conductor temperature: 90 °C  
Conductor: Copper, plain, stranded (class 2)  
Insulation: Halogenfree cross-linked polyalken  
Screen / braid: Plain copper wire braid  
Outer sheath: Halogenfree elastomer

Number of cores Cross-sectional area  
2 x 2 to 24 x 2 0,75 mm<sup>2</sup>

## Application/Limitation

The cables have been approved for firm laying, preferable on ships of the Federal Armed Forces.

## Type Approval documentation

Test Report: VDE Certificate of conformity with factory surveillance  
Certificate No. 40001128 / Ref. No.2306700-5970-0063 / 206134, dated 2014-12-08

BAAINBw Certificate of Approval No. U3.3h/14087, dated 10.12.2014

Specification: VG 95218-63:2013-12

## Tests carried out

| Standard      | Issued  | General description                                                                                                                                                                       | Limitation |
|---------------|---------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|
| VG 95218-63   | 2013-12 | Electrical cables and insulated wires — Part 62: Cable with screen and sheath, pair formation, screened, halogenfree, low fire hazard                                                     |            |
| VG 95218-2    | 2009-12 | Cables and insulated wires - Part 2: Generic specification                                                                                                                                |            |
| IEC 60332-1-2 | 2015-07 | Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable –Procedure for 1 kW pre-mixed flame |            |

Job Id: **262.1-028178-1**  
Certificate No: **TAE000036B**

## Marking of product

Example:

Prysmian Kabel und Systeme GmbH - FMSGSGO - size - voltage rating - VDE-REG-Nr

## Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE