

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Heat Shrinkable Tubing**

with type designation(s)

Heat shrinkable wrap around: MRSM

Issued to

**Tyco Electronics Raychem GmbH
Ottobrunn, Germany**

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.**Issued at **Hamburg** on **2019-04-11**This Certificate is valid until **2024-04-10**.DNV GL local station: **Augsburg**for **DNV GL**Approval Engineer: **Carsten Hunsalz**

**Arne Schaarmann
Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Job Id: **262.1-009445-5**
Certificate No: **TAE00003DU**

Product description

Component		Colour	Property	Material / Product Specification
Wrap-around	Coating			
MRSM		Black with thermosensitive paint	Flame retarded	PPS 3010/06
-239	Adhesive	Red	Sealant against moisture	PPS 3012/70

List of sizes:

Type MRSM wrap around	Inside diameter		Wall thickness
	As supplied Minimum (mm)	After free recovery, Maximum (mm)	After free recovery, Minimum (mm)
Size			
50/23	50	23	1,8
73/38	73	38	1,8
100/51	100	51	1,8

Application/Limitation

For protection and or insulation of cables and wires.
Voltage: Max 1000 V.
Temperature class: -30 °C to +90 °C
Dielectric Strength: 130 kV/cm Min.

Type Approval documentation

Tests carried out

Heat cycling, Insulation resistance, Flexibility/ bend cycling, Flame resistance (IEC 60332-1).

Marking of product

Raychem – Product type – size – batch no.



Job Id: **262.1-009445-5**
Certificate No: **TAE00003DU**

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE