

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Low Voltage Cable**

with type designation(s)
250V PXY, PXY-S, PXY(C), PXY(I), PXY(I/C)

Issued to

Kukdong Electric Wire Co., Ltd.
Jincheon-gun, Chungcheongbuk-do, Republic of Korea

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft
IEC 60092-376 (2017-05)

Application :**Instrumentation and communication**

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Rated voltage (V) 250
Temp. class (°C) 90

Issued at **Busan** on **2019-04-10**

This Certificate is valid until **2024-03-26**.

for **DNV GL**

DNV GL local station: **Seoul**

Approval Engineer: **Eun Jin Lee**

.....
Andreas Kristoffersen
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

Type : 250V PXY, PXY-S, PXY(C), PXY(I), PXY(I/C)

Conductor: Stranded tinned annealed copper conductor, Class 2
Insulation: HEPR
Individual screen: AL/PS mylar tape with drain wire ('I' type)
Individual screen: Tinned annealed copper wire braid ('S' type)
Common screen: AL/PS mylar tape with drain wire ('C' type)
Outer sheath : PVC(ST2)

Type	No. of cores x conductor cross-section
PXY	2~77C x 1.0 mm ²
PXY-S	2~77C x 1.0 mm ²
PXY(C)	Pair : 1~48 x 0.75 mm ² , 1.0mm ² , 1.5mm ² Triad : 1~48 x 0.75 mm ² , 1.0mm ² , 1.5mm ²
PXY(I), PXY(I/C)	Pair : 1~48 x 0.75 mm ² , 1.0mm ² , 1.5mm ² Triad : 1~48 x 0.75 mm ² , 1.0mm ² , 1.5mm ²

Application/Limitation

The requirement of SOLAS Chapter II-1 Part D Reg. 45, 5.2 to limit Fire Propagation along Bunches of Cables or Wires are fulfilled without any additional measures.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
IEC 60092-376	2017-05	Cables for control and instrumentation circuits 150/250V(300V)	
IEC 60092-360	2014-04	Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation, telecommunication cables	
IEC 60332-1	2015-07	Test for vertical flame propagation for a single insulated wire or cable	
IEC 60332-3-22	2009-02	Test for vertical flame spread of vertically mounted bunched wires or cables	Cat. A
IEC 60811-504	2012-03	Bending tests at low temperature for insulations and sheaths	@-30 °C
IEC 60811-506	2012-03	Impact test at low temperature for insulations and sheaths	@-30 °C
IEEE1580	2010	Recommended practice for Marine cable for Use on shipboard and fixed or floating facilities	Oil resistant 70°C /4 hrs

Marking of product

250V - Cable type - Size - KUKDONG - IEC 60332-3 A - Year - Length

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)

Job Id: **262.1-027832-2**
Certificate No: **TAE00003H1**

- Results from Routine tests (RT) and selected type tests (ref. to applicable class programs) checked (if not available these tests shall be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE