

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Electric Power Cable**

with type designation(s)

HFX-A/CU-L 0,6/1 kV VFD (EMC) & FHFX-A/CU-L 0,6/1 kV VFD (EMC), HFX-A/CU-L 1,8/3 kV VFD (EMC) & FHFX-A/CU-L 1,8/3 kV VFD (EMC)

Issued to

Prysmian Cavi e Sistemi Italia S.r.l.
Milano, MI, Italy

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.**

Type	Rated voltage (kV)	Temp. class (°C)
HFX-A/CU-L 0,6/1 kV VFD (EMC) & FHFX-A/CU-L 0,6/1 kV VFD (EMC)	0,6/1	90
HFX-A/CU-L 1,8/3 kV VFD (EMC) & FHFX-A/CU-L 1,8/3 kV VFD (EMC)	1,8/3	90

Issued at **Hamburg** on **2020-07-15**This Certificate is valid until **2025-07-14**.for **DNV GL**DNV GL local station: **Italy/Malta CMC**Approval Engineer: **Carsten Hunsalz****Arne Schaarmann**
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV GL AS, its parent companies and subsidiaries as well as their officers, directors and employees ("DNV GL") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

HFX-A/CU-L 0,6/1 kV VFD (EMC) & FHFX-A/CU-L 0,6/1 kV VFD (EMC),
HFX-A/CU-L 1,8/3 kV VFD (EMC) & FHFX-A/CU-L 0,6/1 kV VFD (EMC)

Construction:

Conductors: Plain or tinned, stranded copper class 2 or 5 (F=Flexible)
Core insulation: HF-XLPE
Inner covering: Synthetic and/or fire retardant tape(s)
Metal covering: PET/Cu tape (plain Cu) + Plain or tinned copper wire braid
Outer sheath: SHF1

0,6/1 kV (1 core)

Number of cores x conductor cross- section mm ²	*Overall diameter nom. cl. 5 mm
1 x 6 /2,5	8,5
1 x 10 /2,5	9,0
1 x 16 /4	10,3
1 x 25 /4	12,5
1 x 35 /4	13,5

0,6/1 kV (3 or 4 core)

Number of cores x conductor cross- section mm ²	*Overall diameter nom. cl. 5 mm
4G 6	16,6
4G 10	18,8
4G 16	21,8
3 x 25 /16	24,2
3 x 35 /16	26,6
3 x 50 /25	31,5
3 x 70 /35	35,5
3 x 95 /50	40,0

0,6/1 kV (3+3 core)

Number of cores x conductor cross- section mm ²	*Overall diameter nom. cl. 5 mm
3x25+3G 6	24,5
3x35+3G 6	26,8
3x50+3G 10	30,5
3x70+3G 16	34,9
3x95+3G 16	40,9
3x120+3G 25	45,0
3x150+3G 25	48,9

1,8/3 kV (3+3 core)

Number of cores x conductor cross- section mm ²	*Overall diameter nom. cl. 5 mm
3x10+3G 4	22,6
3x16+3G 6	24,6
3x25+3G 6	27,8
3x35+3G 6	30,1
3x50+3G 10	32,9
3x70+3G 16	37,2
3x95+3G 16	42,5
3x120+3G 25	46,4
3x150+3G 25	49,4
3x185+3G 35	55,4
3x240+3G 50	60,7

*Indicative

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Flame retardant Cat. A. Halogen free. Low smoke.

Job Id: **262.1-033258-1**
Certificate No: **TAE000040Z**

Type Approval documentation

Test report: Prysmian no. 052/20 18/06/2020, 01SK00134,
CN15S0390911-01, CN14S0291735-01, CN14S0291735-02

Specification: Prysmian STSX-1-1956 Rev.1 23/04/2014

Tests carried out

Standard	Release	General description	Limitation
IEC 60092-350	2020-01	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-353	2016-09	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60332-1-2	2016-09	Tests on electric cables under fire conditions. Test for vertical flame propagation for a single insulated wire or cable.	
IEC 60332-3-22	2018-07	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 60684-2	2011-08	Flexible insulating sleeving – Part 2: Methods of test. Fluorine	Fluorine content < 0,1%
IEC 61034-1/2	2013-06	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance >60%

Marking of product

Example:

PRYSMIAN (P) - HFX-A/CU-L 0,6/1 kV VFD (EMC) - Size - IEC 60332-3-22 Cat. A – Year - OdL - Meter Marking

Job Id: **262.1-033258-1**
Certificate No: **TAE000040Z**

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE