DNV·GL

Certificate No:
TAE000041Y

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Low Voltage Cable

with type designation(s)
MYHCY

Issued to
HEW-Kabel GmbH
Wipperfürth, Nordrhein-Westfalen, Germany

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.
Rated voltage (V) 300/500
Temp. class (°C) 90

Issued at **Hamburg** on **2020-12-07**
This Certificate is valid until **2025-12-06**.
DNV GL local station: **Essen**

Approval Engineer: **Carsten Hunsalz**

for **DNV GL**

Arne Schaarmann
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV GL AS, its parent companies and subsidiaries as well as their officers, directors and employees ("DNV GL") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Job Id: **262.1-033870-1**
Certificate No: **TAE000041Y**

Product description

Halogen free, flame retardant TPE-E insulated, armoured and TPE-O sheathed power and control cable

Type: MYHCY

Rated Voltage:	300/500 V
Maximum operating conductor temperature: 90° C	
Conductor:	Stranded bare copper conductor up to 2,5mm² (class 2) and from 4 mm² up to 10 mm² (class 5)
Insulation:	TPE-E-112 (Thermoplast Polyester Eleastomer 12Y)
Armour/screen:	Bare copper braid
Sheath:	TPE-O-107 or TPE-O-108 (Thermoplast Polyolefin- Elastomer 18Y)

Number of cores:	Cross-section area:
2 to 24	0,75 mm² up to 1,5 mm²
2 to 5	2,5 mm²
2 to 4	2.5 mm² up to 6 mm²
2 + 4	10 mm²

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Flame retardant Cat. A. Halogen free. Low smoke.

Type Approval documentation

Test Report:	HEW Zulassung Prüfplan 89158.xls, 16.06.2004 VDE 657400-9020-0001/60406+38040 FG42/hz
Data Sheet:	TD-Number 20675-001

Tests carried out

Standard	Release	General description	Limitation
DIN 89158	2017-06	Electric cables for ships and offshore units - Power cables with shield (armour)	partly
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	partly
IEC 60332-1-2 AMD1	2004-07 2015-07	Tests on electric and optical fibre cables under fire conditions - Part 1-2: Test for vertical flame propagation for a single insulated wire or cable - Procedure for 1 kW pre-mixed flame	
IEC 60332-3-22	2018-07	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.

Standard	Release	General description	Limitation
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 60684-2	2011-08	Clause 45.2 Methods of determination of low levels of fluorine	HF max 0,1%
IEC 61034-1/2	2013-06	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance >60%

Marking of product

HEW-KABEL - DNV GL No. TAE000041Y – MYHCY - size – 300/500V – IEC 60332-3-22 - special text

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE