

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Low Voltage Cable

with type designation(s)

**CHEF82/DA/SA, CHEFP82/DA/SA, CHEF92/DA/SA, CHEFP92/DA/SA, CHEPJ85/SC,
CHEPJP85/SC, CHEPJ95/SC, CHEPJP95/SC**

Issued to

Yangzhou Guangming Cable Co., Ltd
YANGZHOU, JIANGSU, China

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Rated voltage (V) 150/250

Temp. class (°C) 90

Issued at **Hamburg** on **2020-11-19**

This Certificate is valid until **2025-11-18**.

DNV GL local station: **Nanjing NB & CMC**

for **DNV GL**

Approval Engineer: **Carsten Hunsalz**

.....
Arne Schaarmann
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV GL AS, its parent companies and subsidiaries as well as their officers, directors and employees ("DNV GL") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

EPR insulated shipboard control and instrumentation cables

Rated voltage:	150/250 V
Maximum operating conductor temperature:	90° C
Conductor:	Tinned stranded copper, class 2
Insulation:	EPR
Individual screen:	P - Tinned copper
Inner sheath:	F - SE, PJ - SHF2
Armour / braid:	8 - Copper wire braid 9 - Galvanized steel wire braid
Outer sheath:	2 - ST2, 5 - SHF2
No. of pair units:	Nominal cross section mm ²
1 - 48	0.75, 1, 1.5, 2.5

Application/Limitation

Control and instrumentation.

The following applies to SA and SC type cables only:

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

The following applies to SC type cables only:

Flame retardant Cat. A. Halogen free. Low smoke.

Type Approval documentation

Test report:	CT05-0102-4, CT14-3770, CT05-0102-3 Yangzhou Guangming sample test report GL-05-01-04 Yangzhou Guangming sample test report GL-05-01-03 CT10-1112A-3, CT10-1112A-4
--------------	---

Tests carried out

Standard	Release	General description	Limitation
IEC 60092-350	2020-01	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-376	2017-05	Cables for control and instrumentation circuits 150/250 V (300 V)	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60332-1-2 AMD1	2004-07 2015-07	Tests on electric and optical fibre cables under fire conditions - Part 1-2: Test for vertical flame propagation for a single insulated wire or cable - Procedure for 1 kW pre-mixed flame	

Job Id: **262.1-033881-1**
Certificate No: **TAE000043T**

Standard	Release	General description	Limitation
IEC 60332-3-22*	2018-07	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60754-1**	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2**	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 60684-2**	2011-08	Clause 45.2 Methods of determination of low levels of fluorine	Fluorine content < 0,1%
IEC 61034-1/2**	2013-06	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance >60%

* SA and SC type only

** SC type only

Marking of product

Example:

Yangzhou Guangming Cable Co., Ltd - CHEPJ85/SC – 150/250 – size - IEC 60332-3-22* - Lot no.

* SA and SC type only

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE