



Certificate No:
TAE0000463

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Data transmission cables and systems

with type designation(s)
TKSEA CANBUS LSZH CABLE

Issued to

TecniKabel S.p.A.
Volpiano TO, Italy

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

Data communication cable.

Products approved by this certificate are accepted for installation on all vessels classed by DNV.

Issued at **Høvik** on **2022-05-04**

This Certificate is valid until **2027-05-03**.

DNV local station: **Milan**

Approval Engineer: **Ivar Bull**

for **DNV**

Trond Sjøvåg
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: TA 251

Revision: 2021-03

www.dnv.com

Page 1 of 3

Product description

TKSEA CANBUS LSZH CABLE (1 or 2 or 4 pairs). Optional: Arctic grade -65 °C

Rated voltage peak:	100 V	
Conductor:	Stranded bare copper	
Insulation:	Foam-Skin Polyolefine	
Individual Screen:	Aluminum/Polyester tape	(for one pair only)
Inner sheath:	SHF1	(for two pairs only)
Collective Screen:	Tinned copper wire braid $\geq$ 80% coverage	(for one pair only)
Collective Screen:	A. Aluminum/Polyester tape B. Tinned copper wire braid $\geq$ 80% coverage	(for two pairs and four pairs only) (for two pairs and four pairs only)
Outer sheath:	SHF1 or SHF2 or SHF2 MUD RESISTANT	
Number of cores:	One or two or four pairs 0,75 mm ²	
Earth conductor:	1x 0,75 mm ²	(for one pair only)

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Operation:	-40°C + 70°C (SHF1) -40°C + 90°C (SHF2 & SHF2 MUD) -65°C + 90 °C (arctic SHF2)
Installation:	-10°C + 50°C -20°C + 50 °C (arctic SHF2)

Type Approval documentation

Tests carried out

Standard	Issued	General description	Limitation
IEC 61158-2	2014-07	Industrial communication networks - Fieldbus specifications - Part 2: Physical layer specification and service definition	Standard test cable 12.8.2 a) to g)
IEC 60332-1-2	2004-07	Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame	
IEC 60754-1	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2019-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 61034-1/2	2019-11	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance >60%
IEC 60332-3-22	2018-07	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
EN 50305 9.2	2002	Railway applications - Railway rolling stock cables having special fire performance - Test methods	Toxicity of evolved gas <3

Standard	Issued	General description	Limitation
UL 2565-99 Cycle 1		ASTM D 2565 – 99 SUNLIGHT RESISTANCE (XENON ARC TEST)	41,5 W/m ² 300-400nm. Temp. 63 °C. 18min spray/102min dry Duration 720 h. Max change in E@B ±40%
IEC 60092-360	2021-01	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	SHF1. SHF2: IRM 902 _ 100° C 24 h
NEK TS 606 Ed5	2016	Cables for offshore installations. Halogen-free and/or mud resistant. Technical specification.	SHF2 MUD versions: IRM902 100°C 7d. IRM903 100°C 7d. Calcium Bromide 70°C 56d. EDC 95/11 70°C 56d
IEC 60092-350	2020-01	Electrical installations in ships - Part 350: General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications Annex E: Cold bend test and impact test for low temperature behaviour	Cold bend: -65°C Cold impact: -55°C

Marking of product

TECNIKABEL (A) – ITALY - month/year - TKSEA CANBUS 1x2x0,75 mm² /0,75mm² or 2x2x0,75 mm² or 4x2x0,75 mm²
LSZH CABLE SHF1 or SHF2 or SHF2 MUD RESISTANT - Approval marks – IEC 60332-3-22 - metric marking

TECNIKABEL (A) – ITALY - month/year - TKSEA ARCTIC CANBUS 1x2x0,75 mm² /0,75mm² or 2x2x0,75 mm² or 4x2x0,75 mm²
LSZH CABLE SHF2 -65°C/+90°C - Approval marks – IEC 60332-3-22 - metric marking

A = Almese plant

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE