

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Electric Power Cable

with type designation(s)

**LKSM-ALU,
LKSM-EMC-ALU,
LKSM-VFD-ALU,
LKSM-ALU-SHF2,
LKSM-EMC-ALU-SHF2,
LKSM-VFD-ALU-SHF2**

Issued to

HELKAMA BICA OY
Kaarina, Finland

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

Armoured Power and control cable with aluminum conductors.

Products approved by this certificate are accepted for installation on all vessels classed by DNV.

Type	Rated voltage (kV)	Temp. class (°C)
LKSM-ALU	0,6/1	90
LKSM-EMC-ALU	0,6/1	90
LKSM-VFD-ALU	1,8/3	90
LKSM-ALU-SHF2	0,6/1	90
LKSM-EMC-ALU-SHF2	0,6/1	90
LKSM-VFD-ALU-SHF2	1,8/3	90

Issued at **Høvik** on **2021-11-25**

This Certificate is valid until **2026-11-24**.

DNV local station: **Turku**

for **DNV**

Approval Engineer: **Ivar Bull**

.....
Trond Sjøvåg
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

LKSM-ALU,
LKSM-EMC-ALU,
LKSM-VFD-ALU,
LKSM-ALU-SHF2,
LKSM-EMC-ALU-SHF2,
LKSM-VFD-ALU-SHF2

Construction LKSM-ALU:

Conductor: Stranded aluminum class 5 similar to IEC 60228 class 5 Cu conductors.
Resistance according to IEC 60228 class 2 aluminium.

Core insulation: XLPE

Dummy cores: Optional

Inner covering: Tape

Metal covering: Plain (optional tinned) copper wires braid

Sheath: SHF1 or SHF2

	No of cores:	Cross sectional area [mm ²]
LKSM-ALU	1, 2, 3, 4, 5	35 - 185

Construction LKSM-EMC-ALU, LKSM-VFD-ALU:

Conductor: Stranded aluminum class 5 similar to IEC 60228 class 5 Cu conductors.
Resistance according to IEC 60228 class 2 aluminium.

Core insulation: XLPE

Dummy cores: Optional for EMC cables or VFD cables without earth conductors

3x Distributed earth conductors: Copper, 1/6 of main conductor (optional for VFD cables)

Inner covering: Tape

Screen: Cu-tape

Metal covering: Plain (optional tinned) copper wires braid

Sheath: SHF1 or SHF2

	No of cores:	Cross sectional area [mm ²]
LKSM-EMC-ALU	1, 2, 3, 4, 5	35 - 185
LKSM-VFD-ALU	1, 3	35 - 185

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

1. Cable shall be terminated with DNV type approved terminations from Gustav Klauke GmbH designed for aluminum conductors, ref. DNV TA certificate **TAE00004DV**.
2. Installation to be performed by trained personnel according to Klauke installation Instructions.
3. In order to prevent ingress of moisture, heat shrink tubing with melt glue shall be installed over pressed termination and overlap cable sheath.

DNV Rules Part 4 Chapter 8 Section 9 [1.1.3] states: "The design of all electrical cables installed shall comply with the requirements of applicable IEC Publications." Further, Section 1 Service Description [1.1.4] states: "The Society will consider the use of alternative standards if they are found to represent an overall safety concept equivalent to that of the rules."

Based on passed tests in DNV Class program CP-0409, DNV considers the aluminum cables and terminations listed in this certificate to represent an equivalent safety level as traditional copper cables.

At termination points, marking signs shall inform that service and repair work on cable terminations require special equipment and tools to maintain safety level of aluminum cable system.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
DNV-CP-0399	2021-08	Electric cables	
IEC 60092-350	2020-01	Electrical installations in ships - Part 350: General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-360	2021-01	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables	
IEC 60092-353	2016-09	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	
IEC 60092-354	2020-02	Electrical installations in ships – Part 354: Single- and three-core power cables with extruded solid insulation for rated voltages 6 kV up to 30 kV.	
IEC 60092-376	2017-05	Cables for control and instrumentation circuits 150/250 V (300 V)	
IEC 60332-1-2:2004 +AMD1:2015	2004	Tests on electric and optical fibre cables under fire conditions - Part 1-2: Test for vertical flame propagation for a single insulated wire or cable - Procedure for 1 kW pre-mixed flame	Flame retardant small scale
IEC 60332-3-22	2018-07	Tests on electric and optical fibre cables under fire conditions - Part 3-22: Test for vertical flame spread of vertically mounted bunched wires or cables - Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60754-1	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 61034-1/2	2019-11	Measurement of smoke density of cables burning under defined conditions – Part 1: Test apparatus Part 2: Test procedure and requirements	Low smoke Light transmittance >60%

Marking of product

HELKAMA - LKSM-ALU - size - 0,6/1 kV- IEC 60332-3-22 – Lot no
HELKAMA - LKSM-EMC-ALU - size - 0,6/1 kV- IEC 60332-3-22 – Lot no
HELKAMA - LKSM-VFD-ALU - size – 1,8/3 kV- IEC 60332-3-22 – Lot no

HELKAMA - LKSM-ALU-SHF2 - size - 0,6/1 kV- IEC 60332-3-22 – Lot no
HELKAMA - LKSM-EMC-ALU-SHF2 - size - 0,6/1 kV- IEC 60332-3-22 – Lot no
HELKAMA - LKSM-VFD-ALU-SHF2 - size – 1,8/3 kV- IEC 60332-3-22 – Lot no

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine tests (RT) and selected type tests (ref. to applicable class programs) checked (if not available these tests shall be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE