



Certificate No:
TAE00004CY

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Low Voltage Cable

with type designation(s)

PIOI, PIOI(C), PIBI, PIBI(C), PICI, PICI(C), PIOI(I), PIBI(I), PIOI(I/C), PIBI(I/C)

Issued to

LS Cable & System Ltd (Donghae Plant)
Donghae-si, Gangwon-do, Korea, Republic of

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft
IEC 60092-376 (2017-05)

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Control and instrumentation cable

Rated voltage (V) 250

Temp. class (°C) 90

Issued at **Busan** on **2021-11-22**

This Certificate is valid until **2026-11-21**.

for **DNV**

DNV local station: **Seoul**

Approval Engineer: **Eun Jin Lee**

.....
Hanwee Low
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: TA 251

Revision: 2021-03

www.dnv.com

Page 1 of 3

Product description

Type designation : 250V PIOI, PIOI(C), PIBI, PIBI(C), PICI, PICI(C), PIOI(I), PIBI(I), PIOI(I/C), PIBI(I/C)

Conductors:	Tinned stranded copper, class 2
Insulation:	HF HEPR
Screen:	(C): Collective screen with drain wire, Aluminium/polyester tape (I): Individual screen with drain wire, (I/C): Individual & collective screen with drain wire
Inner sheath:	SHF1
Armor :	Galvanized steel(C), Bronze(B) or Copper(O) wire braid
Outer sheath:	SHF1

Cable type	No. of Pairs	Conductor size(mm ²)
PIOI, PIOI(C), PIBI, PIBI(C), PICI, PICI(C)	2C~77C	1.0
PIOI(C), PIBI(C), PIOI(I), PIBI(I), PIOI(I/C), PIBI(I/C)	1P~48P	0.75, 1.0, 1.5
	1T~48T	0.75, 1.0, 1.5

Application/Limitation

The requirements of SOLAS Chapter II-1 Part D Reg. 45.5.2 to limit Fire Propagation along Bunches of Cables or Wires are fulfilled without any additional measures.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
IEC 60092-376	2017	Cables for control and instrumentation circuits 150/250V(300V)	
IEC 60092-360	2021	Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation, telecommunication cables	
IEC 60332-1	2015	Test for vertical flame propagation for a single insulated wire or cable	
IEC 60332-3-22	2018	Test for vertical flame spread of vertically mounted bunched wires or cables	Cat. A
IEC 60754-1/2	2019	Test on gases evolved during combustion of materials from cables – Determination of the amount of halogen acid gas / Determination of the degree of acidity of gases evolved during the combustion of materials taken from electric cables by measuring pH and conductivity	Low Halogen <0,5% Halogen free ≥4,3pH, ≤10μS/mm
IEC 61034-1/2	2019	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke >60%
IEC 60092-350 Annex E	2020	Cold bend test and impact test for low temperature behaviour	Cold bend: -30°C Cold impact: -30°C

Marking of product

[HIS]-RATING-TYPE-SIZE-LS CABLE-YEAR-LENGTH-STANDARD
EX) [HIS] 250V PIOI 44CX1.0 LS CABLE 2015 XXXM IEC 60332 CAT.A

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine tests (RT) and selected type tests (ref. to applicable class programs) checked (if not available these tests shall be carried out)



Job Id: **262.1-019515-2**
Certificate No: **TAE00004CY**

- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE