

TYPE APPROVAL CERTIFICATE

This is to certify:

That the High Voltage Cable

with type designation(s)

F-RFOU-VFD 3,6/6 kV, F-RFOU-VFD M 3,6/6 kV, F-RFOU-VFD 6/10 kV, F-RFOU-VFD M 6/10 kV, F-RFOU-VFD 8,7/15 kV, F-RFOU-VFD M 8,7/15 kV, F-RFOU-VFD 12/20 kV, F-RFOU-VFD M 12/20 kV

Issued to

Prysmian Cavi e Sistemi Italia S.r.l.
Milano, MI, Italy

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Type	Rated voltage (kV)	Temp. class (°C)
F-RFOU-VFD 3,6/6 kV, F-RFOU-VFD M 3,6/6 kV	3,6/6	90
F-RFOU-VFD 6/10 kV, F-RFOU-VFD M 6/10 kV	6/10	90
F-RFOU-VFD 8,7/15 kV, F-RFOU-VFD M 8,7/15 kV	8,7/15	90
F-RFOU-VFD 12/20 kV, F-RFOU-VFD M 12/20 kV	12/20	90

Issued at **Hamburg** on **2021-10-19**

This Certificate is valid until **2026-10-18**.

for **DNV**

DNV local station: **Italy/Malta CMC**

Approval Engineer: **Carsten Hunsalz**

.....
Arne Schaarmann
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

NEK Type:

F-RFOU-VFD 3,6/6 kV, F-RFOU-VFD M 3,6/6 kV (MUD resistant)
F-RFOU-VFD 6/10 kV, F-RFOU-VFD M 6/10 kV (MUD resistant)
F-RFOU-VFD 8,7/15 kV, F-RFOU-VFD M 8,7/15 kV (MUD resistant)
F-RFOU-VFD 12/20 kV, F-RFOU-VFD M 12/20 kV (MUD resistant) same as

IEC Type:

CU/HEPR/EMC/SHF2, CU/HEPR/EMC/SHF2 MUD 3,6/6 kV or 6/10 kV or 8,7/15 kV or 12/20 kV

Construction: 3 phase conductors + 3 distributed earth conductors in interstices.
Conductors: Tinned, stranded copper class 5 (class 2 on request)
Cond. Screening: Semi-conducting layer
Core insulation: HF-HEPR
Insul. Screening: Semi-conducting layer + tinned copper wire braid
Inner covering or sheath: Halogen-free compound
EMC Screen: PET/Cu tape with 100% coverage
Metal covering: Tinned copper wire braid
Outer sheath: SHF2 or SHF2 MUD

Type: F-RFOU-VFD 3,6/6 kV, F-RFOU-VFD M 3,6/6 kV (MUD resistant):

No of cores:	Cross sectional area [mm ²]
3 + E	25 – 240 / 3x Earth 6 -50

Type: F-RFOU-VFD 6/10 kV, F-RFOU-VFD M 6/10 kV (MUD resistant):

No of cores:	Cross sectional area [mm ²]
3 + E	25 – 240 / 3x Earth 6 -50

Type: F-RFOU-VFD 8,7/15 kV, F-RFOU-VFD M 8,7/15 kV (MUD resistant):

No of cores:	Cross sectional area [mm ²]
3 + E	25 – 185 / 3x Earth 6 -35

Type: F-RFOU-VFD 12/20 kV, F-RFOU-VFD M 12/20 kV (MUD resistant) same as:

No of cores:	Cross sectional area [mm ²]
3 + E	25 – 185 / 3x Earth 6 -35

Application/Limitation

High voltage power.

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Flame retardant Cat. A. Halogen free. Low smoke.
Mud resistant. Cold bend -40°C. Cold impact -35°C.

Type Approval documentation

Tests carried out

Standard	Issued	General description	Limitation
IEC 60092-350	2020-01	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-354	2020-02	Electrical installations in ships - Part 354: Single- and three-core power cables with extruded solid insulation for rated voltages 6 kV (Um = 7,2 kV) up to 30 kV (Um = 36 kV)	

Standard	Issued	General description	Limitation
IEC 60092-360	2021-01	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60332-3-22	2018-07	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60332-1-2	2015-07	Tests on electric cables under fire conditions. Test for vertical flame propagation for a single insulated wire or cable.	
IEC 60754-1	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2019-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 60684-2	2011-08	Clause 45.2 Methods of determination of low levels of fluorine	Fluorine content < 0,1%
IEC 61034-1/2	2019-11	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance >60%
CSA C22.2 No. 03	2009	4.12 Flexibility at any specified temperature	Cold bend: - 40°C
CSA C22.2 No. 03	2009	4.13 Abnormal low temperature – impact	Cold impact: -35°C
NEK TS 606	2016	Cables for offshore installations. Halogen-free and/or mud resistant. Technical specification.	

Marking of product

Example:

PRYSMIAN (P) – F-RFOU-VFD 6/10 kV SHF2 or F-RFOU-VFD M 6/10 kV SHF2 MUD - Size - IEC 60332-3-22 – Year - Meter marking

Place of Production

Prysmian Cavi e Sistemi Italia S.r.l., Merlino, Italy

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE