

TYPE APPROVAL CERTIFICATE

This is to certify:

That the High Voltage Cable

with type designation(s)

CJPF86/SC, CJPJ85/SC, CJPF96/SC, CJPJ95/SC, CJPF86/SC, CJPJ85/SC, CJPF96/SC, CJPJ95/SC, CJPF86/SC, CJPJ85/SC, CJPF96/SC, CJPJ95/SC, CJPF86/SC, CJPJ85/SC, CJPF96/SC, CJPJ95/SC

Issued to

Zhongtian Technology Industrial Wire & Cable System Co.,Ltd.
Nantong, China

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

High voltage power cables.

Products approved by this certificate are accepted for installation on all vessels classed by DNV.

Type	Rated voltage (kV)	Temp. class (°C)
CJPF86/SC, CJPJ85/SC, CJPF96/SC, CJPJ95/SC	3,6/6 kV	90
CJPF86/SC, CJPJ85/SC, CJPF96/SC, CJPJ95/SC	6/10 kV	90
CJPF86/SC, CJPJ85/SC, CJPF96/SC, CJPJ95/SC	8,7/15 kV	90
CJPF86/SC, CJPJ85/SC, CJPF96/SC, CJPJ95/SC	12/20 kV	90
CJPF86/SC, CJPJ85/SC, CJPF96/SC, CJPJ95/SC	18/30 kV	90

Issued at **Høvik** on **2022-10-21**

This Certificate is valid until **2027-10-20**.

for **DNV**

DNV local station: **Nantong CMC**

Approval Engineer: **Ivar Bull**

.....
Frederik Tore Elter
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

Types:

CJPF86/SC, CJPJ85/SC, CJPF96/SC, CJPJ95/SC	3,6/6 kV
CJPF86/SC, CJPJ85/SC, CJPF96/SC, CJPJ95/SC	6/10 kV
CJPF86/SC, CJPJ85/SC, CJPF96/SC, CJPJ95/SC	8,7/15 kV
CJPF86/SC, CJPJ85/SC, CJPF96/SC, CJPJ95/SC	12/20 kV
CJPF86/SC, CJPJ85/SC, CJPF96/SC, CJPJ95/SC	18/30 kV

Construction:

Conductors:	Tinned or plain stranded copper class 2 or class 5
Conductor screen:	Semi conducting material
Core insulation:	XLPE
Insulation screen:	Semi conducting material and tinned copper wire or copper tape wrap
Inner sheath:	SHF1 or SHF2
Braid armour:	Copper or galvanized steel wire braid
Outer sheath:	SHF1 or SHF2

Single cores :

Voltage U0 / U [kV]				
3,6/6	6/10	8,7/15	12/20	18/30
1 x 10	-	-	-	-
1 x 16	1 x 16	-	-	-
1 x 25	1 x 25	1 x 25	-	-
1 x 35	1 x 35	1 x 35	1 x 35	-
1 x 50	1 x 50	1 x 50	1 x 50	1 x 50
1 x 70	1 x 70	1 x 70	1 x 70	1 x 70
1 x 95	1 x 95	1 x 95	1 x 95	1 x 95
1 x 120	1 x 120	1 x 120	1 x 120	1 x 120
1 x 150	1 x 150	1 x 150	1 x 150	1 x 150
1 x 185	1 x 185	1 x 185	1 x 185	1 x 185
1 x 240	1 x 240	1 x 240	1 x 240	1 x 240
1 x 300	1 x 300	1 x 300	1 x 300	1 x 300
1 x 400	1 x 400	1 x 400	1 x 400	1 x 400

3 cores :

Voltage U0 / U [kV]				
3,6/6	6/10	8,7/15	12/20	18/30
3 x 10	-	-	-	-
3 x 16	3 x 16	-	-	-
3 x 25	3 x 25	3 x 25	-	-
3 x 35	3 x 35	3 x 35	3 x 35	-
3 x 50	3 x 50	3 x 50	3 x 50	3 x 50
3 x 70	3 x 70	3 x 70	3 x 70	3 x 70
3 x 95	3 x 95	3 x 95	3 x 95	3 x 95
3 x 120	3 x 120	3 x 120	3 x 120	3 x 120
3 x 150	3 x 150	3 x 150	3 x 150	3 x 150
3 x 185	3 x 185	3 x 185	3 x 185	3 x 185
3 x 240	3 x 240	3 x 240	3 x 240	3 x 240
3 x 300	3 x 300	3 x 300	3 x 300	3 x 300
3 x 400	3 x 400	3 x 400	3 x 400	3 x 400

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bundles of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Tests carried out

Standard	Issued	General description	Limitation
IEC 60092-350	2020-01	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-360	2021-01	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60092-354	2020-02	Electrical installations in ships - Part 354: Single- and three-core power cables with extruded solid insulation for rated voltages 6 kV (Um = 7,2 kV) up to 30 kV (Um = 36 kV)	
IEC 60332-1-2	2018-03	Tests on electric cables under fire conditions. Test for vertical flame propagation for a single insulated wire or cable.	

Standard	Issued	General description	Limitation
IEC 60332-3-22	2018-07	Tests on electric cables under fire conditions - Part 3-22: Test for vertical flame spread of vertically mounted bunched wires or cables - Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60754-1:2011 +AMD1:2019 CSV	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2:2011 +AMD1:2019 CSV	2019-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10μS/mm
IEC 61034-1&2:2005 +AMD1:2013 +AMD2:2019 CSV	2019-11	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance >60%
IEC 60684-2	2011-08	Flexible insulating sleeving – Part 2: Methods of test Clause 45.1 Methods of determination of low levels of chlorine, and/or Bromine and/or iodine Clause 45.2 Methods of determination of low levels of fluorine	HCl + HBr + HJ max 0,5% [0,014% can be detected] HF max 0,1% [0,02% can be detected]

Marking of product

Zhongtian Technology Industrial Wire and Cable System Co. LTD – CJPJ86/SC of CJPJ85/SC of CJPJ96/SC or CJPJ95/SC, – 3,6/6 kV or 6/10kV or 8,7/15kV or 12/20kV or 18/30kV - IEC 60332-3-22 Cat. A – Year

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine tests (RT) and selected type tests (ref. to applicable class programs) checked (if not available these tests shall be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE