



Certificate No:
TAE00004MY

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Electric Power Cable

with type designation(s)

H-FLEX PWR PUR SHORE CONNECTION 3x185mm² 0,6/1 kV

Issued to

Helkama Bica Oy
Kaarina, Finland

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

Highly flexible power and control cable compliant IEC 80005-3 Annex A Ship to shore cable.

Products approved by this certificate are accepted for installation on all vessels classed by DNV.

Rated voltage (kV) 0,6/1

Temp. class (°C) 90

Issued at **Høvik** on **2023-01-01**

This Certificate is valid until **2027-12-31**.

for **DNV**

DNV local unit: **Finland CMC**

Approval Engineer: **Ivar Bull**

Frederik Tore Elter
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

Type: H-FLEX SHORE CONNECTION PWR C-PUR 0,6/1 kV

Construction:

Power Conductors: Plain (optional tinned) stranded copper class 5
Core insulation: XLPE
Strength elements: Optional to achieve higher tensile strength and protect from antitwist
Inner covering: Tape wrapping
Metal covering: Plain (optional tinned) copper wires braid. Filling factor >0,6
Outer sheath: PUR

H-FLEX PWR PUR 0,6/1 kV, H-FLEX PWR C-PUR 0,6/1 kV

No of cores:	Cross sectional area [mm ²]
3 power conductors	185
3x earth conductors	35
2 pairs of pilot conductors	Minimum 1,5

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
DNV CP-0399	2021-08	Electric cables.	
IEC 60092-350	2020-01	Electrical installations in ships - Part 350: General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-360	2021-01	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables	
IEC 60092-353	2016-09	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	
IEC 60332-1-2	2015-07	Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame	
IEC 60332-3-22	2018-07	Tests on electric and optical fibre cables under fire conditions - Part 3-22: Test for vertical flame spread of vertically mounted bunched wires or cables - Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60754-1	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 61034-1/2	2019-11	Measurement of smoke density of cables burning under defined conditions – Part 1: Test apparatus Part 2: Test procedure and requirements	Low smoke Light transmittance >60%
EN 50363-10-2	2006	Insulating, sheathing and covering materials for low voltage energy cables - Part 10-2: Miscellaneous sheathing compounds - Thermoplastic polyurethane	

Standard	Release	General description	Limitation
EN 50396-6.2	2005	Insulating, sheathing and covering materials for low voltage energy cables - Part 6: Halogen-free, cross-linked sheathing compounds	
IEC PAS 80005-3	2014	Utility connections in port – Part 3: Low Voltage Shore Connection (LVSC) Systems – General requirements	Annex A (normative) Ship-to-shore connection cable

Marking of product

HELKAMA - H-FLEX PWR PUR SHORE CONNECTION 0,6/1 kV – 3x185mm² + 3E35mm + P1/P2+P3/P4 - 0,6/1 kV– IEC 60332-3-22 - IEC PAS 80005-3 Lot No.

Pilot conductors shall be marked P1,P2 and P3,P4

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine tests (RT) and selected type tests (ref. to applicable class programs) checked (if not available these tests shall be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years.
A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE