



Certificate no.:
TAE00004U1

TYPE APPROVAL CERTIFICATE

This is to certify:

that the **Electric Power Cable**

with type designation(s)
CJPJ85/SC, CJPF86/SC

issued to

Jiangsu Jiangyang Special Cable Co., Ltd.
Yangzhou, China

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application:

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Rated voltage (kV) 1,8/3

Temp. class (°C) 90

Issued at **Høvik** on **2023-11-22**

This Certificate is valid until **2028-11-21**.

for **DNV**

DNV local unit: **Nanjing NB & CMC**

Approval Engineer: **Carsten Hunsalz**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: TA 251

Revision: 2023-09

www.dnv.com

Page 1 of 3

Product description

Type: CJPJ85/SC, CJPF86/SC 1,8/3 kV

Conductors: Plain or tinned stranded copper Class 2 or Class 5
Insulation: XLPE
Inner sheath: PF – SHF1
PJ – SHF2
Armor: 8 – Tinned copper wire braid
Outer sheath: 5 – SHF2
6 – SHF1

Conductor number x cross section	Cable diameter nom. Class 2	Cable diameter nom. Class 5
1×10	13,1	13,6
1×16	14,5	14,9
1×25	16,1	16,3
1×35	17,5	17,7
1×50	18,9	19,4
1×70	20,7	21,2
1×95	23,0	23,5
1×120	24,9	25,3
1×150	26,6	27,1
1×185	28,7	29,1
2×10	22,6	23,0
2×16	24,8	25,2
2×25	28,0	28,4
2×35	30,8	31,2
2×50	33,4	33,8
2×70	37,8	38,2
2×95	42,0	42,4
2×120	45,8	46,2
2×150	49,2	49,6
2×185	53,2	53,6
3×10	24,1	24,6
3×16	26,5	26,9
3×25	29,7	30,2
3×35	32,7	33,1
3×50	35,7	36,1
3×70	40,6	41,0
3×95	45,1	45,5
3×120	49,0	49,4
3×150	52,6	53,0
3×185	57,3	57,7

Conductor number x cross section	Cable diameter nom. Class 2	Cable diameter nom. Class 5
4×10	26,4	26,9
4×16	29,1	29,5
4×25	32,9	33,3
4×35	36,2	36,6
4×50	40,1	40,5
4×70	44,8	45,3
4×95	50,0	50,5
4×120	54,5	55,0
4×150	58,6	59,0
4×185	63,8	64,2
5×10	28,9	29,5
5×16	32,0	32,6
5×25	36,2	36,7
5×35	40,4	41,0
5×50	44,1	44,6
5×70	49,3	49,9
5×95	55,1	55,6
5×120	60,3	60,8
5×150	64,7	65,2
5×185	70,4	71,0

Application/Limitation

General power and lighting. Control.

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bundles of Cables or Wires) are fulfilled without any additional measures.

Flame retardant Cat. A. Halogen free. Low smoke.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
IEC 60092-350	2020-01	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-353	2016-09	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	
IEC 60092-360	2021-01	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60332-1-2	2015-07	Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame	
IEC 60332-3-22	2018-07	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60754-1	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2019-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 60684-2	2011-08	Clause 45.2 Methods of determination of low levels of fluorine	Fluorine content < 0,1%
IEC 61034-1/2	2019-11	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance >60%

Marking of product

Example:

Jiangsu Jiangyang Special Cable Co., Ltd. - CJPJ85/SC - 1,8/3 kV - size - IEC 60332-3-22 - Lot no.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE