



Certificate no.:
TAE00004YX

TYPE APPROVAL CERTIFICATE

This is to certify:

that the **Low Voltage Cable**

with type designation(s)
BFOU (I/C)

issued to

Thermo Cables Ltd
Jedcherala, Telangana, India

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application:

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Rated voltage (V) 150/250

Temp. class (°C) 90

Issued at **Hamburg** on **2024-12-17**

This Certificate is valid until **2029-12-16**.

for **DNV**

DNV local unit: **India CMC MES**

Approval Engineer: **Carsten Hunsalz**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

Product description

Type: BFOU (I/C)

Construction

Conductors:	Tinned, stranded copper class 2 or class 5
Core insulation:	Mica tape + EPR
Individual shielding:	Al Mylar tape with drain wire
Overall shielding:	Al Mylar tape with drain wire
Inner sheath:	SHF2
Metal covering:	Tinned copper or galvanised steel wire braid
Outer sheath:	SHF2

Number of pairs	Cross section [mm ²]	Overall Diameter [mm]
2	0,5	15,10
1	0,75	10,70
2	0,75	15,90
3	0,75	16,80
4	0,75	18,20
5	0,75	19,70
6	0,75	21,40
7	0,75	21,40
8	0,75	23,80
9	0,75	25,70
10	0,75	26,80
11	0,75	26,80
12	0,75	27,70
13	0,75	29,00
14	0,75	29,00
15	0,75	30,60
16	0,75	30,60
17	0,75	32,20
18	0,75	32,20
19	0,75	32,20
20	0,75	34,00
21	0,75	34,00
22	0,75	36,30
23	0,75	36,30
24	0,75	38,10
25	0,75	38,10
26	0,75	38,10
27	0,75	38,90
30	0,75	40,30
32	0,75	41,90
37	0,75	43,50
40	0,75	45,30
44	0,75	49,00
48	0,75	49,80
50	0,75	50,90

Number of pairs	Cross section [mm ²]	Overall Diameter [mm]
1	1,5	12,10
2	1,5	18,30
3	1,5	19,40
4	1,5	21,10
5	1,5	23,00
6	1,5	25,00
7	1,5	25,00
8	1,5	28,00
9	1,5	30,30
10	1,5	31,60
11	1,5	31,60
12	1,5	32,70
13	1,5	34,80
14	1,5	34,80
15	1,5	36,70
16	1,5	36,70
17	1,5	38,70
18	1,5	38,70
19	1,5	38,70
20	1,5	40,90
21	1,5	40,90
22	1,5	43,20
23	1,5	43,20
24	1,5	45,40
25	1,5	45,40
26	1,5	45,40
27	1,5	46,40
30	1,5	48,10
32	1,5	50,00
37	1,5	52,00
40	1,5	54,20
44	1,5	58,70
48	1,5	59,70
50	1,5	61,00

Number of pairs	Cross section [mm ²]	Overall Diameter [mm]
1	2,5	13,40
2	2,5	19,90
3	2,5	21,10
4	2,5	23,10
5	2,5	25,20
6	2,5	27,40
7	2,5	27,40
8	2,5	30,80
9	2,5	33,40
10	2,5	35,30
11	2,5	35,30
12	2,5	36,50
13	2,5	38,30
14	2,5	38,30
15	2,5	40,50
16	2,5	40,50
17	2,5	42,70
18	2,5	42,70
19	2,5	42,70
20	2,5	45,20
21	2,5	45,20
22	2,5	47,70
23	2,5	47,70
24	2,5	50,20
25	2,5	50,20
26	2,5	50,20
27	2,5	51,30
30	2,5	53,30
32	2,5	55,40
37	2,5	57,70
40	2,5	60,10
44	2,5	65,10
48	2,5	66,20
50	2,5	67,70

Application/Limitation

This type of cable is fire resistant in accordance with IEC Publication 60331.

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bundles of Cables or Wires) are fulfilled without any additional measures.

Instrumentation, communication and control.

Fire resistant. Flame retardant in bunch Cat. A. Halogen free. Low smoke.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
IEC 60092-350	2020-01	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-376	2017-05	Cables for control and instrumentation circuits 150/250 V (300 V)	
IEC 60092-360	2021-01	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60331-1/2	2018-03	Fire resistance / Circuit integrity – Test for method for fire with shock at temperature of at least 830°C for cables rated up to and including 0,6/1 kV	120 min.
IEC 60332-1-2	2015-07	Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable –Procedure for 1 kW pre-mixed flame	
IEC 60332-3-22	2018-07	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60754-1	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2019-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 60684-2	2011-08	Flexible insulating sleeving – Part 2: Methods of test.	Fluorine content < 0,1%
IEC 61034-1/2	2019-11	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance >60%

Marking of product

Example

Thermo Cables Ltd - BFOU (I/C) - size - 150/250V - IEC 60331-1/2 - IEC 60332-3-22 Cat.A - Lot no.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE