



Certificate no.:
TAE000053F

TYPE APPROVAL CERTIFICATE

This is to certify:

that the **Low Voltage Cable**

with type designation(s)
CHJPJ/NC, CHJJPJ/NC, CHJPF/NC, CHJFPF/NC

issued to

Guangzhou OUSSEA Photoelectric Transmission Technology Inc., Ltd.
Guangzhou, Guangdong Province, China

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application:

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Rated voltage (V) 150/250

Temp. class (°C) 90

Issued at **Hamburg** on **2025-10-09**

This Certificate is valid until **2030-10-08**.

for **DNV**

DNV local unit: **China South NB**

Approval Engineer: **Carsten Hunsalz**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

Product description

Type: CHJPJ/NC, CHJPJP/NC, CHJPF/NC, CHJPFP/NC

Conductor: Tinned, stranded copper class 2 or class 5
Insulation: Mica tape + XLPE
Individual screen: P - Tinned copper wire braid
Collective screen: Tinned copper wire only for variants without individual screen
Outer sheath: PF - (SHF1) or PJ - (SHF2)

CHJPJ/NC, CHJPF/NC

Number of cores x conductor cross- section	Overall diameter nom.
mm ²	mm
1 x2x0,5	6,8
2 x2x0,5	10,5
3 x2x0,5	10,6
4 x2x0,5	11,6
5 x2x0,5	12,7
6 x2x0,5	13,9
7 x2x0,5	13,9
8 x2x0,5	15,7
10 x2x0,5	18,0
12 x2x0,5	18,7
14 x2x0,5	19,7
16 x2x0,5	20,9
18 x2x0,5	22,1
19 x2x0,5	22,1
24 x2x0,5	26,2
27 x2x0,5	26,8
30 x2x0,5	27,8
33 x2x0,5	29,0
37 x2x0,5	30,2
43 x2x0,5	33,0
48 x2x0,5	35,0
1 x2x0,75	7,2
2 x2x0,75	11,1
3 x2x0,75	11,3
4 x2x0,75	12,5
5 x2x0,75	13,7
6 x2x0,75	15,0
7 x2x0,75	15,0
8 x2x0,75	17,0
10 x2x0,75	19,4
12 x2x0,75	20,2
14 x2x0,75	21,3

Number of cores x conductor cross- section	Overall diameter nom.
mm ²	mm
16 x2x0,75	22,6
18 x2x0,75	23,8
19 x2x0,75	23,8
24 x2x0,75	28,3
27 x2x0,75	28,9
30 x2x0,75	30,1
33 x2x0,75	31,4
37 x2x0,75	32,7
43 x2x0,75	35,7
48 x2x0,75	37,8
1 x2x1	8,5
2 x2x1	13,3
3 x2x1	13,6
4 x2x1	15,0
5 x2x1	16,6
6 x2x1	18,2
7 x2x1	18,2
8 x2x1	20,7
10 x2x1	23,7
12 x2x1	24,6
14 x2x1	26,0
16 x2x1	27,5
18 x2x1	29,2
19 x2x1	29,2
24 x2x1	34,6
27 x2x1	35,5
30 x2x1	36,9
33 x2x1	38,5
37 x2x1	40,2
43 x2x1	43,8
48 x2x1	46,5

Number of cores x conductor cross- section	Overall diameter nom.
mm ²	mm
1 x2x1,5	9,2
2 x2x1,5	14,3
3 x2x1,5	14,8
4 x2x1,5	16,3
5 x2x1,5	18,0
6 x2x1,5	19,9
7 x2x1,5	19,9
8 x2x1,5	22,6
10 x2x1,5	25,8
12 x2x1,5	26,8
14 x2x1,5	28,3
16 x2x1,5	30,0
18 x2x1,5	31,8
19 x2x1,5	31,8
24 x2x1,5	37,9
27 x2x1,5	38,8
30 x2x1,5	40,4
33 x2x1,5	42,1
37 x2x1,5	43,9
43 x2x1,5	47,9
48 x2x1,5	50,8
1 x2x2,5	10,2
2 x2x2,5	16,1
3 x2x2,5	16,6
4 x2x2,5	18,4
5 x2x2,5	20,4
6 x2x2,5	22,4
7 x2x2,5	22,4
8 x2x2,5	25,6
10 x2x2,5	29,4
12 x2x2,5	30,4
14 x2x2,5	32,2

Number of cores x conductor cross- section	Overall diameter nom.
mm ²	mm
16 x2x2,5	34,2
18 x2x2,5	36,3
19 x2x2,5	36,3
24 x2x2,5	43,2
27 x2x2,5	44,3
30 x2x2,5	46,0
33 x2x2,5	48,0
37 x2x2,5	50,1
43 x2x2,5	54,7
48 x2x2,5	58,1

CHJJP/NC, CHJFP/NC

Number of cores x conductor cross- section	Overall diameter nom.
mm ²	mm
1 x2x0,5	6,9
2 x2x0,5	11,4
3 x2x0,5	11,6
4 x2x0,5	12,8
5 x2x0,5	14,1
6 x2x0,5	15,5
7 x2x0,5	15,5
8 x2x0,5	17,6
10 x2x0,5	20,1
12 x2x0,5	20,8
14 x2x0,5	21,9
16 x2x0,5	23,3
18 x2x0,5	24,6
19 x2x0,5	24,6
24 x2x0,5	29,2
27 x2x0,5	29,9
30 x2x0,5	31,1
33 x2x0,5	32,4
37 x2x0,5	33,8
43 x2x0,5	36,8
48 x2x0,5	39,1
1 x2x0,75	7,3
2 x2x0,75	12,2
3 x2x0,75	12,5
4 x2x0,75	13,8
5 x2x0,75	15,1
6 x2x0,75	16,6
7 x2x0,75	16,6
8 x2x0,75	18,9
10 x2x0,75	21,6
12 x2x0,75	22,3
14 x2x0,75	23,6

Number of cores x conductor cross- section	Overall diameter nom.
mm ²	mm
16 x2x0,75	25,0
18 x2x0,75	26,5
19 x2x0,75	26,5
24 x2x0,75	31,5
27 x2x0,75	32,3
30 x2x0,75	33,6
33 x2x0,75	35,0
37 x2x0,75	36,5
43 x2x0,75	39,8
48 x2x0,75	42,2
1 x2x1	8,6
2 x2x1	14,6
3 x2x1	15,0
4 x2x1	16,5
5 x2x1	18,2
6 x2x1	20,1
7 x2x1	20,1
8 x2x1	22,9
10 x2x1	26,2
12 x2x1	27,2
14 x2x1	28,7
16 x2x1	30,4
18 x2x1	32,3
19 x2x1	32,3
24 x2x1	38,4
27 x2x1	39,4
30 x2x1	40,9
33 x2x1	42,7
37 x2x1	44,6
43 x2x1	48,7
48 x2x1	51,6

Number of cores x conductor cross- section	Overall diameter nom.
mm ²	mm
1 x2x1,5	9,3
2 x2x1,5	15,6
3 x2x1,5	16,2
4 x2x1,5	17,9
5 x2x1,5	19,9
6 x2x1,5	21,8
7 x2x1,5	21,8
8 x2x1,5	24,8
10 x2x1,5	28,5
12 x2x1,5	29,6
14 x2x1,5	31,3
16 x2x1,5	33,2
18 x2x1,5	35,2
19 x2x1,5	35,2
24 x2x1,5	41,9
27 x2x1,5	42,9
30 x2x1,5	44,6
33 x2x1,5	46,5
37 x2x1,5	48,6
43 x2x1,5	53,1
48 x2x1,5	56,2
1 x2x2,5	10,3
2 x2x2,5	17,6
3 x2x2,5	18,2
4 x2x2,5	20,3
5 x2x2,5	22,4
6 x2x2,5	24,7
7 x2x2,5	24,7
8 x2x2,5	28,2
10 x2x2,5	32,4
12 x2x2,5	33,6
14 x2x2,5	35,5

Number of cores x conductor cross- section	Overall diameter nom.
mm ²	mm
16 x2x2,5	37,7
18 x2x2,5	40,0
19 x2x2,5	40,0
24 x2x2,5	47,6
27 x2x2,5	48,8
30 x2x2,5	50,8
33 x2x2,5	53,0
37 x2x2,5	55,3
43 x2x2,5	60,5
48 x2x2,5	64,1

CHJPJ/NC, CHJPF/NC

Number of cores x conductor cross- section	Overall diameter nom.	Number of cores x conductor cross- section	Overall diameter nom.	Number of cores x conductor cross- section	Overall diameter nom.	Number of cores x conductor cross- section	Overall diameter nom.
mm ²	mm	mm ²	mm	mm ²	mm	mm ²	mm
1 x3x0,5	7,1	16 x3x0,75	25,6	1 x3x1,5	9,7	16 x3x2,5	39,0
2 x3x0,5	11,6	18 x3x0,75	27,1	2 x3x1,5	16,1	18 x3x2,5	41,3
3 x3x0,5	11,9	19 x3x0,75	27,1	3 x3x1,5	16,6	19 x3x2,5	41,3
4 x3x0,5	13,0	24 x3x0,75	32,2	4 x3x1,5	18,4	24 x3x2,5	49,2
5 x3x0,5	14,3	27 x3x0,75	32,9	5 x3x1,5	20,4	27 x3x2,5	50,4
6 x3x0,5	15,7	30 x3x0,75	34,3	6 x3x1,5	22,4	30 x3x2,5	52,5
7 x3x0,5	15,7	33 x3x0,75	35,7	7 x3x1,5	22,4	33 x3x2,5	54,7
8 x3x0,5	17,9	37 x3x0,75	37,2	8 x3x1,5	25,6	37 x3x2,5	57,1
10 x3x0,5	20,4	43 x3x0,75	40,7	10 x3x1,5	29,4	43 x3x2,5	62,5
12 x3x0,5	21,1	48 x3x0,75	43,1	12 x3x1,5	30,4	48 x3x2,5	66,3
14 x3x0,5	22,3			14 x3x1,5	32,2		
16 x3x0,5	23,7	1 x3x1	9,1	16 x3x1,5	34,2		
18 x3x0,5	25,1	2 x3x1	14,9	18 x3x1,5	36,3		
19 x3x0,5	25,1	3 x3x1	15,3	19 x3x1,5	36,3		
24 x3x0,5	29,8	4 x3x1	16,9	24 x3x1,5	43,2		
27 x3x0,5	30,4	5 x3x1	18,8	27 x3x1,5	44,2		
30 x3x0,5	31,6	6 x3x1	20,6	30 x3x1,5	46,0		
33 x3x0,5	33,0	7 x3x1	20,6	33 x3x1,5	47,9		
37 x3x0,5	34,4	8 x3x1	23,4	37 x3x1,5	50,1		
43 x3x0,5	37,6	10 x3x1	26,9	43 x3x1,5	54,6		
48 x3x0,5	39,8	12 x3x1	28,0	48 x3x1,5	58,0		
		14 x3x1	29,5				
1 x3x0,75	7,6	16 x3x1	31,3	1 x3x2,5	10,9		
2 x3x0,75	12,4	18 x3x1	33,2	2 x3x2,5	18,1		
3 x3x0,75	12,7	19 x3x1	33,2	3 x3x2,5	18,9		
4 x3x0,75	14,0	24 x3x1	39,5	4 x3x2,5	20,9		
5 x3x0,75	15,4	27 x3x1	40,5	5 x3x2,5	23,1		
6 x3x0,75	16,9	30 x3x1	42,1	6 x3x2,5	25,5		
7 x3x0,75	16,9	33 x3x1	43,9	7 x3x2,5	25,5		
8 x3x0,75	19,2	37 x3x1	45,8	8 x3x2,5	29,0		
10 x3x0,75	22,0	43 x3x1	50,0	10 x3x2,5	33,5		
12 x3x0,75	22,9	48 x3x1	53,0	12 x3x2,5	34,6		
14 x3x0,75	24,2			14 x3x2,5	36,7		

CHJJP/NC, CHJFP/NC

Number of cores x conductor cross- section	Overall diameter nom.	Number of cores x conductor cross- section	Overall diameter nom.	Number of cores x conductor cross- section	Overall diameter nom.	Number of cores x conductor cross- section	Overall diameter nom.
mm ²	mm	mm ²	mm	mm ²	mm	mm ²	mm
1 x3x0,5	7,3	16 x3x0,75	28,3	1 x3x1,5	9,9	16 x3x2,5	42,7
2 x3x0,5	12,7	18 x3x0,75	30,0	2 x3x1,5	17,6	18 x3x2,5	45,3
3 x3x0,5	13,0	19 x3x0,75	30,0	3 x3x1,5	18,2	19 x3x2,5	45,3
4 x3x0,5	14,3	24 x3x0,75	35,6	4 x3x1,5	20,2	24 x3x2,5	54,1
5 x3x0,5	15,9	27 x3x0,75	36,5	5 x3x1,5	22,3	27 x3x2,5	55,4
6 x3x0,5	17,4	30 x3x0,75	38,0	6 x3x1,5	24,6	30 x3x2,5	57,7
7 x3x0,5	17,4	33 x3x0,75	39,6	7 x3x1,5	24,6	33 x3x2,5	60,1
8 x3x0,5	19,7	37 x3x0,75	41,2	8 x3x1,5	28,1	37 x3x2,5	62,7
10 x3x0,5	22,6	43 x3x0,75	45,0	10 x3x1,5	32,3	43 x3x2,5	68,6
12 x3x0,5	23,4	48 x3x0,75	47,7	12 x3x1,5	33,5	48 x3x2,5	72,8
14 x3x0,5	24,7			14 x3x1,5	35,4		
16 x3x0,5	26,2	1 x3x1	9,2	16 x3x1,5	37,6		
18 x3x0,5	27,8	2 x3x1	16,2	18 x3x1,5	39,8		
19 x3x0,5	27,8	3 x3x1	16,8	19 x3x1,5	39,8		
24 x3x0,5	33,0	4 x3x1	18,6	24 x3x1,5	47,5		
27 x3x0,5	33,8	5 x3x1	20,6	27 x3x1,5	48,6		
30 x3x0,5	35,1	6 x3x1	22,7	30 x3x1,5	50,6		
33 x3x0,5	36,6	7 x3x1	22,7	33 x3x1,5	52,8		
37 x3x0,5	38,2	8 x3x1	25,8	37 x3x1,5	55,1		
43 x3x0,5	41,7	10 x3x1	29,6	43 x3x1,5	60,2		
48 x3x0,5	44,2	12 x3x1	30,8	48 x3x1,5	63,8		
		14 x3x1	32,5				
1 x3x0,75	7,8	16 x3x1	34,4	1 x3x2,5	11,0		
2 x3x0,75	13,6	18 x3x1	36,6	2 x3x2,5	19,7		
3 x3x0,75	13,9	19 x3x1	36,6	3 x3x2,5	20,6		
4 x3x0,75	15,4	24 x3x1	43,5	4 x3x2,5	22,9		
5 x3x0,75	17,0	27 x3x1	44,6	5 x3x2,5	25,3		
6 x3x0,75	18,7	30 x3x1	46,4	6 x3x2,5	28,0		
7 x3x0,75	18,7	33 x3x1	48,4	7 x3x2,5	28,0		
8 x3x0,75	21,3	37 x3x1	50,5	8 x3x2,5	31,8		
10 x3x0,75	24,4	43 x3x1	55,2	10 x3x2,5	36,6		
12 x3x0,75	25,3	48 x3x1	58,5	12 x3x2,5	38,0		
14 x3x0,75	26,7			14 x3x2,5	40,2		

Application/Limitation

Control and instrumentation.

This type of cable is fire resistant in accordance with IEC Publication 60331.

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bundles of Cables or Wires) are fulfilled without any additional measures.

Fire resistant. Flame retardant Cat. A. Halogen free. Low smoke.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
DNV-CP-0399	2021-08	Class Programme Electric cables	
IEC 60092-350	2020-01	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-376	2025-04	Cables for control and instrumentation circuits 150/250 V (300 V)	
IEC 60092-360	2021-01	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60332-1-2	2015-07	Tests on electric cables under fire conditions. Test for vertical flame propagation for a single insulated wire or cable.	
IEC 60332-3-22	2018-07	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60331-1	2018-03	Fire resistance / Circuit integrity – Test for method for fire with shock at temperature of at least 830°C for cables rated up to and including 0,6/1 kV with an overall diameter exceeding 20 mm	For cables with an overall diameter exceeding 20 mm, 120 min.
IEC 60331-2	2018-03	Fire resistance / Circuit integrity – Test for method for fire with shock at temperature of at least 830°C for cables rated up to and including 0,6/1 kV with an overall diameter not exceeding 20mm	For cables with an overall diameter not exceeding 20 mm, 120 min.
IEC 60754-1	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2019-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 60684-2	2011-08	Clause 45.2 Methods of determination of low levels of fluorine	HF max 0,1%
IEC 61034-1/2	2019-11	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance >60%

Marking of product

Example:

Guangzhou OUSSEA Photoelectric Transmission Technology Inc., Ltd. - CHJPJ/NC – 150/250V - size -
IEC 60332-3-22 – IEC 60331-1/2 - Lot no.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE