



Certificate no.:
TAE000055E

TYPE APPROVAL CERTIFICATE

This is to certify:

that the **Multifunction Relay**

with type designation(s)
PowerLogic P7

issued to

Schneider Electric Industries SAS
Rueil Malmaison, France

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application:

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Issued at **Høvik** on **2026-01-22**

This Certificate is valid until **2031-01-21**.

for **DNV**

DNV local unit: **Netherlands VMC**

Approval Engineer: **Nikolai Arntzen**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

Product description

PowerLogic P7 is a platform of digital protection and control devices for modern Power Systems that provides hardware and firmware flexibility.

PowerLogic P7 devices support customized device functionality without change of the device firmware. Within the chosen application level, the user can freely configure the available functions and features in the corresponding application templates.

The main application selected defines the protection functions available in the application template.

P7M – Motor protection

P7G – Generator protection

P7F – Feeder protection

P7T – Transformer protection

P7S – Stand-alone Merging Unit (SAMU)

Functions	ANSI code	IEC 61850 Logical node
Current protection functions		
Phase overcurrent	50/51	<i>PHPTOC</i>
Phase direction	67	<i>PHRDIR</i>
Ground fault overcurrent	50N/51	<i>EFPTOC</i>
Ground direction	67N	<i>EFRDIR</i>
Sensitive ground fault overcurrent	50SG/ 51SG	<i>VSEFPTOC</i>
Negative sequence overcurrent	46	<i>NPSPTOC</i>
Directional negative sequence overcurrent	46/67Q	<i>NPSRDIR</i>
Inrush detection	68ID	<i>IDPHAR</i>
Selective overcurrent logic (SOL)	SOL	<i>SOLGAPC</i>
Phase undercurrent	37	<i>PHPTUC</i>
Voltage dependent overcurrent	51V	<i>PHPVOC</i>
Sensitive directional earthfault	67SG/ 32N	<i>PSDE</i>
Switch on to fault	SOTF	<i>PSOF</i>
Ground admittance	21YN	<i>EFPADM</i>
Broken conductor	46BC	<i>BCPTOC</i>
Voltage protection functions		
Phase overvoltage	59	<i>PHPTOV</i>
Neutral overvoltage	59N	<i>EFPTOV</i>
Positive phase sequence overvoltage	59D	<i>PPSPTOV</i>
Negative phase sequence overvoltage	47	<i>NPSPTOV</i>
Phase undervoltage	27	<i>PHPTUV</i>
Positive phase sequence undervoltage	27D	<i>PPSPTUV</i>
Overfluxing	24	<i>PVPH</i>
Rate of voltage change	ROCOV	<i>PVRC</i>
Frequency protection functions		
Overfrequency	81O	<i>PTOF</i>
Underfrequency	81U	<i>PTUF</i>
Underfrequency load shedding	81LS	<i>LSPTUF</i>
Frequency rate of change	81R	<i>PFRC</i>
Differential protection functions		
High impedance diff	87/64G	<i>HIZPDIF</i>
Bias differential	87	<i>PHPDIF</i>
Restricted ground fault	64G	<i>RGFPDIF</i>
Basic transformer differential	87T	<i>TR2PDIF</i>
Advanced transformer differential	87T	<i>TR3PDIF</i>
Temperature protection functions		

Motor thermal overload	49M	THMPTTR
Thermal overload	49	THFPTTR
Overtemperature	38/49RTD	STMP
Machine unbalance	46	NPSPTR
Motor protection functions		
Motor monitoring		ZMOT
Motor start supervision	48	PMSS
Locked rotor	51LR	JAMPTOC
Motor restart inhibit	66	PMRI
Voltage check	47	VCPTUV
Generator protection functions		
Third harmonic undervoltage	27TN	STPTUV
Interturn overvoltage	59IT	ITPTOV
Interturn overcurrent	50SP	ITPDIF
Inadvertent energization	50/27	IEPIOC
Speed protection functions		
Overspeed	12	POVS
Underspeed	14	PZSU
Zerospeed	14	ZEROPZSU
Machine speed		TRTN
Distance/impedance protection functions		
Field failure	40	FFPDIS
Underimpedance	21	UZPDIS
Out of step	78	OOSPPAM
Capacitor protection functions		
Capacitor bank monitoring		ZCAP
Capacitor overvoltage	59C	CAPPTOV
Capacitor unbalance	51C	UIBCPTOC
Power protection functions		
Overpower	32P	PPDOP
Reactive overpower	32Q	QPDOP
Underpower	37P	PPDUP
Monitoring functions		
Trip conditioner	86	PTRC
Battery monitoring		ZBAT
Bay status		PDGAPC
Programmable stage		PSGAPC
Temperature		RTD TTMP
Current loop (mA) input		CLTGSN
Current loop (mA) output		CLGGIO
Control functions		
Circuit breaker proxy		CBXCBR
Circuit breaker control	52	CBCSWI
Circuit breaker interlocking		CBCILO
Circuit breaker failure	50BF	RBRF
Circuit breaker supervision		CBSCBR
CB three phase recloser	79	TRIRREC
Switch proxy	89	SWXSWI
Switch control		SWCSWI
Switch interlocking		SWCILO
Switch supervision		SWSSWI
Synchro-check	25	RSYN
Tap changer control	84	YLTC
Logs and records		

Sequence of event record		GENGLOG
Operation log		GENGLOG
Disturbance recorder		DRRDRE
Trend recorder		TRGLOG
Fault records		TCRGLOG
Fault measurement		RFMX
Fault locator		RFLO
Line parameters		ZLIN
Power quality record		PQGLOG
Voltage variation		QVVR
CT group measurement		
CT supervision	60P/60N	CTSSCTR
CT summation		CSTCTT VECACSMMXU RMSACSMMXU CSAMSQI
VT group measurement		
VT supervision	60	VTSSVTR
VT switching		VSTVTT VECVVSMMXU RMSVVSMMXU VVSMSQI
Bay measurement		
Bay measurements		BAYMMXU
Demand values		DVALMMXU
Active and reactive of energy values		EMMTR
Harmonic measurements		MHAI
Process bus functions		
SV subscription		LSVS
SV publication		LSVP

Rated phase current 1A or 5A.
Core balance rated current 1A.
Rated frequency: 50 or 60 Hz.

3 PSU ranges:
Low range: DC: 24...34 V DC
Medium range: DC: 48...125 V DC
High range: DC: 110...250 V DC
AC: 110...250 V AC

Manufactured by

Lexel Fabrika SIA
Krustpils street 35A
Rīga 1073
Latvia

Application/Limitation

Installation of the unit is to be according to manufacturer's specifications.
The total panel instrumentation to be in accordance with the Rules.

Product certificate:

When the unit is used for protection purposes no product certificate is required. When the unit is used for other control purposes a product certificate acc. to Pt.4 Ch.8 Sec.1 and Pt.4 Ch.9 Sec.1 [1.4] will be required. Correct configuration and set up for each delivery to be tested during commissioning after installation.

The Type Approval covers hardware and software for the unit.

The Type Approval does not cover application software.

The following documentation of the actual application is to be submitted for approval in each case:

- System Block Diagram
- Power supply arrangement (may be part of the system block diagram)

The Type Approval covers hardware listed under Product description.

Clause for application software control:

All changes in software are to be recorded. Major changes are to be forwarded to DNV for evaluation and approval.

Major changes in the software are to be approved before installed in the computer. A certification of application functions may be required for the particular vessel.

Required protection (IP) according to the Rules to be provided upon installation on board.

Environmental classes: Vibration A, Temperature D, Humidity B, EMC A.

Type Approval documentation

Tests carried out

Environmental tests in accordance with DNV-CG-0339 edition Aug. 2021: Vibration, Salt mist, Dry heat, Damp heat, Cold and EMC.

Marking of product

Schneider Electric – Type designation

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available.
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines.
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications.
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given.
- Ensuring traceability between manufacturer's product type marking and the type approval certificate.
- Ensuring that type approved documentation is available.

Assessment to be performed at 2 and 3.5 years and at renewal.

END OF CERTIFICATE