

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Structural Fire Protection

with type designation(s)
Pyroclad X1 - Hollow section

Issued to

Carboline Company
St. Louis MO, United States

is found to comply with
DNV GL offshore standards

Application :

Approved for use as a system for fire protection of structural steel hollow sections.

Product approved by this certificate is accepted for installation on all vessels classed by DNV GL.

This Certificate is valid until **2021-12-02**.

Issued at **Høvik** on **2016-12-03**

DNV GL local station: **Houston**

for **DNV GL**

Approval Engineer: **Tomasz Werchowicz**

Petter Langnes
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

Job Id:
Certificate No: **TAF00000G5**

Product description

"Pyroclad X1 - Hollow section"

The system is composed by a primer covered by a 2 part epoxy mastic fire barrier (Pyroclad X1). The intumescent coating is reinforced at approx. 2/3 of desired thickness with high temperature fabric (HTF) with overlap or steel wire mesh (GHC) fixed with pins.

Wet density of Pyroclad X1 is 1035-1110 kg/m³.

The materials are manufactured at the premises of: Carboline Company, 95 Airpark Vista Blvd., Dayton, NV 89403, USA

Application/Limitation

The thickness of "Pyroclad X1" system to be applied to avoid temperatures to rise on the steel substrate less than 200°C, 250°C, 300 °C, 350°C, 400°C, 450°C, 500°C, 550°C and 600°C for "hollow" sections, are given in appendix table 1-9.

The protective coating is not defined as non-combustible and should not be used in accommodation or in enclosed areas.

Potential damage of the structural fire protection material following an explosion has not been considered.

Minimum fabric overlap shall be not less than 50 mm.

The approval refers only to the fire resistance properties of the system.

The application of the protective coating is to be performed in accordance with the manufacturer's application manual. Alternative primers and topcoats may be used provided they have been tested and approved by the manufacture.

Each product is to be supplied with its manual for application and maintenance.

Type Approval documentation

Certification in accordance with Class Programme DNVGL-CP-0338, October 2015.

Pyroclad X1 Fire Barrier System Application Manual, Rev.0, dated October 2012 from Carboline Co., St. Louis, US.

Technical Note No. 071912a dated 19th July 2012 from Carboline Co., St. Louis, US

Test Report No. 100463890SAT-011 dated 23rd July 2012 from Intertek Evaluation Center, Texas, US

Test Report No. 100463890SAT-016 dated 16th June 2012 from Intertek Evaluation Center, Texas, US

Evaluation No. 101513920SAT-008 dated 10th June 2014 from Intertek Testing Services, Texas, US

Tests carried out

Tested according to BS 476: Part 20 with HC-curve according to ISO 834-3.

Marking of product

The product or packing is to be marked with name of manufacturer, type designation and fire-technical rating.

Periodical assessment

DNV GL's surveyor is to be given permission to perform Periodical Assessments at any time during the validity of this certificate and at least every second year. The arrangement is to be in accordance with procedure described in Class Programme DNVGL-CP-0338, Section 4.

Job Id:
Certificate No: **TAF00000G5**

Appendix to certificate TAF00000G5 for Carboline Company

Table 1: Thickness of "PYROCLAD X1" system for fire protection of "hollow" sections for a critical temperature rise of **200°C**:

Hp/A	Fire resistance time in minutes, Thickness in mm						
[m ⁻¹]	30	60	90	120	150	180	240
22							
25							
30							
35							
40							
45							
50							
55							
60							
65							
70							
75							
80							
85							
90							
95							
100							
105							
110							
115							
120							
125							
130							
135							
140							
145							
150							
155							
160							
165							
170							
175							
180							
185							
190							
195							
200							
205							
210							
215							
220							
225							
230							
232							

The maximum thickness of protection material up to the required Hp/A [m⁻¹] shall be used.

Hp/A = Ratio between Heat perimeter and cross sectional Area of the section, [m⁻¹]

Appendix to certificate TAF00000G5 for Carboline Company

Table 2: Thickness of "PYROCLAD X1" system for fire protection of "hollow" sections for a critical temperature rise of **250°C**:

Job Id:
Certificate No: **TAF00000G5**

Hp/A	Fire resistance time in minutes, Thickness in mm						
[m ⁻¹]	30	60	90	120	150	180	240
22							
25							
30							
35							
40							
45							
50							
55							
60							
65							
70							
75							
80							
85							
90							
95							
100							
105							
110							
115							
120							
125							
130							
135							
140							
145							
150							
155							
160							
165							
170							
175							
180							
185							
190							
195							
200							
205							
210							
215							
220							
225							
230							
232							

The maximum thickness of protection material up to the required Hp/A [m⁻¹] shall be used.

Hp/A = Ratio between Heat perimeter and cross sectional Area of the section, [m⁻¹]

Job Id:
Certificate No: **TAF00000G5**

Appendix to certificate TAF00000G5 for Carboline Company

Table 3: Thickness of "PYROCLAD X1" system for fire protection of "hollow" sections for a critical temperature rise of **300°C**:

Hp/A	Fire resistance time in minutes, Thickness in mm						
[m ⁻¹]	30	60	90	120	150	180	240
22							
25							
30							
35							
40							
45							
50							
55							
60							
65							
70							
75							
80							
85							
90							
95							
100							
105							
110							
115							
120							
125							
130							
135							
140							
145							
150							
155							
160							
165							
170							
175							
180							
185							
190							
195							
200							
205							
210							
215							
220							
225							
230							
232							

The maximum thickness of protection material up to the required Hp/A [m⁻¹] shall be used.

Hp/A = Ratio between Heat perimeter and cross sectional Area of the section, [m⁻¹]

Job Id:
Certificate No: **TAF00000G5**

Appendix to certificate TAF00000G5 for Carboline Company

Table 4: Thickness of "PYROCLAD X1" system for fire protection of "hollow" sections for a critical temperature rise of **350°C**:

Hp/A	Fire resistance time in minutes, Thickness in mm						
[m ⁻¹]	30	60	90	120	150	180	240
22							
25							
30							
35							
40							
45							
50							
55							
60							
65							
70							
75							
80							
85							
90							
95							
100							
105							
110							
115							
120							
125							
130							
135							
140							
145							
150							
155							
160							
165							
170							
175							
180							
185							
190							
195							
200							
205							
210							
215							
220							
225							
230							
232							

The maximum thickness of protection material up to the required Hp/A [m⁻¹] shall be used.

Hp/A = Ratio between Heat perimeter and cross sectional Area of the section, [m⁻¹]

Job Id:
Certificate No: **TAF00000G5**

Appendix to certificate TAF00000G5 for Carboline Company

Table 5: Thickness of "PYROCLAD X1" system for fire protection of "hollow" sections for a critical temperature rise of **400°C**:

Hp/A	Fire resistance time in minutes, Thickness in mm						
[m ⁻¹]	30	60	90	120	150	180	240
22							
25							
30							
35							
40							
45							
50							
55							
60							
65							
70							
75							
80							
85							
90							
95							
100							
105							
110							
115							
120							
125							
130							
135							
140							
145							
150							
155							
160							
165							
170							
175							
180							
185							
190							
195							
200							
205							
210							
215							
220							
225							
230							
232							

The maximum thickness of protection material up to the required Hp/A [m⁻¹] shall be used.

Hp/A = Ratio between Heat perimeter and cross sectional Area of the section, [m⁻¹]

Job Id:
Certificate No: **TAF00000G5**

Appendix to certificate TAF00000G5 for Carboline Company

Table 6: Thickness of "PYROCLAD X1" system for fire protection of "hollow" sections for a critical temperature rise of **450°C**:

Hp/A	Fire resistance time in minutes, Thickness in mm						
[m ⁻¹]	30	60	90	120	150	180	240
22							
25							
30							
35							
40							
45							
50							
55							
60							
65							
70							
75							
80							
85							
90							
95							
100							
105							
110							
115							
120							
125							
130							
135							
140							
145							
150							
155							
160							
165							
170							
175							
180							
185							
190							
195							
200							
205							
210							
215							
220							
225							
230							
232							

The maximum thickness of protection material up to the required Hp/A [m⁻¹] shall be used.

Hp/A = Ratio between Heat perimeter and cross sectional Area of the section, [m⁻¹]

Appendix to certificate TAF00000G5 for Carboline Company

Table 7: Thickness of "PYROCLAD X1" system for fire protection of "hollow" sections for a critical temperature rise of **500°C**:

Job Id:
Certificate No: **TAF00000G5**

Hp/A	Fire resistance time in minutes, Thickness in mm						
[m ⁻¹]	30	60	90	120	150	180	240
22							
25							
30							
35							
40							
45							
50							
55							
60							
65							
70							
75							
80							
85							
90							
95							
100							
105							
110							
115							
120							
125							
130							
135							
140							
145							
150							
155							
160							
165							
170							
175							
180							
185							
190							
195							
200							
205							
210							
215							
220							
225							
230							
232							

The maximum thickness of protection material up to the required Hp/A [m⁻¹] shall be used.

Hp/A = Ratio between Heat perimeter and cross sectional Area of the section, [m⁻¹]

Job Id:
Certificate No: **TAF00000G5**

Appendix to certificate TAF00000G5 for Carboline Company

Table 8: Thickness of "PYROCLAD X1" system for fire protection of "hollow" sections for a critical temperature rise of **550°C**:

Hp/A	Fire resistance time in minutes, Thickness in mm						
[m ⁻¹]	30	60	90	120	150	180	240
22							
25							
30							
35							
40							
45							
50							
55							
60							
65							
70							
75							
80							
85							
90							
95							
100							
105							
110							
115							
120							
125							
130							
135							
140							
145							
150							
155							
160							
165							
170							
175							
180							
185							
190							
195							
200							
205							
210							
215							
220							
225							
230							
232							

The maximum thickness of protection material up to the required Hp/A [m⁻¹] shall be used.

Hp/A = Ratio between Heat perimeter and cross sectional Area of the section, [m⁻¹]

Job Id:
Certificate No: **TAF00000G5**

Appendix to certificate TAF00000G5 for Carboline Company

Table 9: Thickness of "PYROCLAD X1" system for fire protection of "hollow" sections for a critical temperature rise of **600°C**:

Hp/A	Fire resistance time in minutes, Thickness in mm						
[m ⁻¹]	30	60	90	120	150	180	240
22							
25							
30							
35							
40							
45							
50							
55							
60							
65							
70							
75							
80							
85							
90							
95							
100							
105							
110							
115							
120							
125							
130							
135							
140							
145							
150							
155							
160							
165							
170							
175							
180							
185							
190							
195							
200							
205							
210							
215							
220							
225							
230							
232							

The maximum thickness of protection material up to the required Hp/A [m⁻¹] shall be used.

Hp/A = Ratio between Heat perimeter and cross sectional Area of the section, [m⁻¹]