DNV·GL

Certificate No:
TAF00000JF

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Class H Lightweight Horizontal Partition and Deck

with type designation(s)
Chartek 8E - Deck (H-0)

Issued to
International Paint Limited
GATESHEAD TYNE AND WEAR, United Kingdom

is found to comply with
DNV GL offshore standards

Application :

Approved for use as a fire retarding deck of class H-0.

This Certificate is valid until **2018-06-30**.

Issued at **Høvik** on **2017-02-21**
DNV GL local station: **Newcastle-upon-Tyne** for **DNV GL**

Approval Engineer: **Helge Bjørnarå**

Petter Langnes
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Job Id: **262.1-009950-6**
Certificate No: **TAF00000JF**

Product description
"Chartek 8E" – Deck (H-0)
composed of a structural steel deck, insulated on the stiffened side (underside) with minimum 4.5 mm epoxy based intumescent coating "Chartek 8E".

The materials are manufactured at the following locations:
- Akzo Nobel Coatings BV, Wapenveld, The Netherlands
- International Paint LLC, Houston, Texas, USA
- International Paint (Korea) Ltd., Haman, Korea
- AkzoNobel Saudi Arabia Ltd., Dammam, Saudi Arabia

Application/Limitation
Approved for use as a fire retarding deck of class H-0_{400}.

The protective coating is not defined as non-combustible, and should not be used in accommodation or in enclosed areas.

The approval refers only to the fire resistance properties of the system.

The application of the protective coating is to be performed in accordance with the manufacturer's application manual. Alternative primers and topcoats may be used provided they have been tested and approved by the manufacture.

Each product is to be supplied with its manual for application and maintenance.

Type Approval documentation
Certification in accordance with Class Programme DNVGL-CP-0338, October 2015.

Test Report No. 142375 dated 3 November 2004 from Warrington Fire Research Centre Ltd, UK.

Tests carried out
Tested according to IMO FTP Code Part 3 (IMO Res. A.754(18)) with furnace temperature following the hydrocarbon curve according to ISO 834-3.

Marking of product
The product or packing is to be marked with name of manufacturer and type designation.

Periodical assessment
DNV GL's surveyor is to be given permission to perform Periodical Assessments at any time during the validity of this certificate and at least every second year. The arrangement is to be in accordance with procedure described in Class Programme DNVGL-CP-0338, Section 4.