

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Equivalent Fixed Gas Fire Extinguishing System**

with type designation(s)

Kidde Fire Systems Marine ECS Novec 1230 Fire Suppression System

Issued to

Kidde-Fenwal**ASHLAND MA, United States**

is found to comply with

DNV GL statutory interpretations DNVGL-SI-0364 – SOLAS interpretations**DNV GL rules for classification – Ships****DNV GL offshore standards****Application :****Approved for use as "total flooding" fire extinguishing system in machinery spaces and cargo pump rooms.****Minimum design gas concentration: 5.85%****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.**Issued at **Høvik** on **2017-06-23**This Certificate is valid until **2022-06-22**.DNV GL local station: **New York**for **DNV GL**Approval Engineer: **Fryderyk Hoga**

Mårten Schei-Nilsson
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

"Kidde Fire Systems Marine ECS Novec 1230 Fire Suppression System"

is an equivalent fixed gas fire extinguishing system composed of gas cylinders with associated cylinder valves, flexible hoses, manifold, section valves, alarms, time delay units, piping and discharge nozzles.

The extinguishing concentration and the nozzles are covered by this type approval certificate. Other components submitted for this type approval are reviewed, but shall be submitted and approved for each project. The system is to be designed in accordance with IMO MSC/Circ.848 as amended by IMO MSC.1/Circ.1267.

The gas is produced by 3M, Cordova, Illinois, USA.

The following associated companies are authorised by Kidde-Fenwal to apply this certificate:

- Kidde-Fenwal Inc., Ashland, USA
- Kidde Fire Protection, Stokenchurch, UK

Kidde Fire Systems Marine ECS Novec 1230 Fire Suppression System physical properties:

Other trade name	FK-5-1-12
Molecular formula	$\text{CF}_3\text{CF}_2\text{C}(\text{O})\text{CF}(\text{CF}_3)_2$
Agent specific vapour volume (S) at 20°C ¹⁾	0.07188 m ³ /kg
Design concentration (C)	5.85 %
Min. agent required (W/V) ²⁾	0.8644 kg/m ³
NOAEL ³⁾	10.0 %
LOAEL ³⁾	>10.0 %

1) To be applied in conjunction with IMO MSC/Circ.848, 3.4.2.3.2

2) When calculated at 20°C. Ambient temperature to be determined case by case for each project

3) NFPA 2001 (2008 Edition)

Application/Limitation

The design gas concentration (diesel) shall be minimum 5.85% (applied on a net volume) and the maximum agent discharge time shall be 10 seconds.

The extinguishing system shall be designed and installed according to SOLAS Ch. II-2, IMO MSC/Circ.848 as amended by IMO MSC.1/Circ.1267 and the Kidde manual.

The following additional limitations will apply:

- Novec 1230 systems are not suitable for the ship's cargo holds. If Novec 1230 systems are installed inside cargo pump rooms, all components shall be certified for use in hazardous areas, the design gas concentration shall be increased and the system is subjected to case by case approval.
- If Novec 1230 is used above its NOAEL (calculated on net volume at max expected ambient temperature), means should be provided to limit exposure (IMO MSC.1/Circ.1267, 6). In no case should Novec 1230 be used in concentrations above its LOAEL.
- Steel storage cylinders of size 10 lb (4.5 kg) to 900 lb (408 kg). Cylinders being 81 L or larger is only accepted when arrangements are provided on board to ensure that cylinders can be easily moved (even to shore) for service and recharging. All cylinders shall be of the same size.
- Gas cylinders shall be delivered on board with a product certificate of the Society or with a certificate issued by a recognized certification authority according to national regulations based on the requirements of the design standard and marked accordingly n, UN or DOT.
- Cylinders are topped up with nitrogen to 25 bar at 21°C. The fill density shall be maximum 1.12 kg/L. Cylinders are to be delivered with DNV product certificate or equivalent certificates acceptable to the flag administration and class.
- Cylinders to be located in a separate room in accordance with SOLAS Ch. II-2 Reg. 10.4.3, or distributed throughout the protected space in accordance with the requirements in IMO MSC/Circ.848 item 11 as amended by IMO MSC.1/Circ.1267. When distributed within the protected space, the min extinguishing concentration (after any single failure) shall be 4.5 %.

- G. Components in the system will be regarded under pressure class II with a maximum design pressure of 35 bar (at 54 °C). Consideration will though be made for piping and couplings inside the protected space.
- H. The nozzles are to be located in accordance with the Kidde manual. A basic rule is that one nozzle can as a maximum cover an area of 5 m x 10 m. A 360° nozzle shall be located centrally in this area, the 180° nozzles on the sides (as applicable). The maximum cover height is 5 m. The minimum average nozzle pressure is 5.5 bar.
- I. Bilges (except open bilges in small volume engine rooms) are to be protected with a dedicated nozzle network.

The following documentation is to be submitted to the flag administration in each case:

- 1. Plans showing location of cylinders, piping, nozzles and release stations as well as the assembled system
- 2. Capacity calculations, including hydraulic flow calculations.
- 3. Plans defining release lines and alarm system.
- 4. Material specification and dimensions for piping and specifications for all other components.
- 5. Ship specific release procedures and post discharge ventilation procedures.
- 6. Manual containing design, inspection, operation and maintenance procedures.
- 7. Control arrangements for closure of openings and stop of fans and any pressure relief devices as per IMO MSC/Circ. 848, 13. These plans can also be supplied by yard.

Testing at installations and periodical surveys

- The system shall be tested as per maker's manual both at installations and at periodical surveys, except that DNV do not require monthly content check of cylinders. The minimum test pressure is minimum 53 bar for any closed sections, whereas open section shall be tightness tested at minimum 7 bar.
- The system is subject to biennial (every 2nd year) inspections by an approved service supplier. The attending surveyor will also apply requirement relevant for flag administration and / or class on newbuilding and ship in operation surveys.

Type Approval documentation

Certification in accordance with Class Programme DNVGL-CP-0338, October 2015.

Design, Installation, Operation and Maintenance Manual – Novec 1230, No. P/N 45-NOVMAR-001, dated June 2012 from Kidde.

Report No. HAI Project #5087, dated 28 June 2002, from Hughes Associates, Inc., Baltimore, USA. (tested on U.S. Coast Guard's Fire & Safety Test Detachment in Mobile, AL)

Report No. 04-CRADA-RDC-001, dated 16 November 2004, from Kidde-Fenwal Inc., Massachusetts, USA. (tested on U.S. Coast Guard's Fire & Safety Test Detachment in Mobile, AL, witnessed by UL)

Report File EX4674, Project 04NK23160, dated February 2005, from UL, Northbrook, USA.

Report No. 3026502, dated 24 March 2006, from FM Approvals, Norwood, USA.

Tests carried out

Tested in accordance with IMO MSC/Circ.848 as amended by IMO MSC.1/Circ.1267.

Marking of product

Main components in the system are to be marked with name of manufacturer and type designation.

Periodical assessment

DNV GL's surveyor is to be given permission to perform Periodical Assessments at any time during the validity of this certificate and at least every second year. The arrangement is to be in accordance with procedure described in Class Programme DNVGL-CP-0338, Section 4.