DNV·GL

Certificate No:
TAF00000ZC

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Equivalent Class A Divisions

with type designation(s)
NON LOADBEARING CLADDING SYSTEM, CLASS A-0

Issued to
IKM DSC Engineering AS
HVALSTAD, Norway

is found to comply with
DNV GL rules for classification – Ships
DNV GL offshore standards
DNV GL statutory interpretations DNVGL-SI-0364 – SOLAS interpretations

Application :

Approved for use as a non-load bearing fire retarding bulkhead of class A-0.

This certificate is recognized by Transport Canada.

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Issued at **Høvik** on **2018-07-01**
This Certificate is valid until **2023-06-30**.
DNV GL local station: **Oslo Maritime and CAP**

Approval Engineer: **Tessa Biever**

for **DNV GL**

Mårten Schei-Nilsson
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Product description
"Non loadbearing cladding system, Class A-0"
composed of non-insulated 2 mm corrugated steel bulkhead.

The product is manufactured at:
- Limeco AB, Uddevalla, Sweden
- BSB Poland Sp.z.o.o, Ciechocin, Poland
- Monik OU, Tallin, Estonia

For further details see test report and drawing listed under Type Approval documentation.

Application/Limitation
Approved for use as a non-load bearing fire retarding bulkhead of class A-0.

The use of this product shall be limited to applications specifically approved by the Administration in question, see IMO 2010 FTP Code part 3, Appendix 1, items 1.12 and 1.13. The construction shall in any case not be used as part of main fire zone bulkheads and stairways enclosures on passenger ships (see also IMO MSC/Circ.1005).

Any surface materials used have to be approved for smoke and toxicity and low flame-spread characteristics (IMO 2010 FTP Code Annex 1 Parts 2 and 5) when required according to relevant rules.

Each product is to be supplied with its manual for installation and use.

Type Approval documentation

Tests carried out
Tested according to IMO 2010 FTP Code Part 3.

Marking of product
The product or packing is to be marked with name of manufacturer, type designation and fire-technical rating.

Transport Canada Approval
Based on the procedures laid down in the Transport Canada Publication entitled "Approval Procedures for, Life Saving Equipment and Structural Fire Protection Products (TP 14612)", DNV GL confirms that the product listed in this certificate is in accordance with Transport Canada's requirements.

Periodical assessment
DNV GL's surveyor is to be given permission to perform Periodical Assessments at any time during the validity of this certificate and at least every second year. The arrangement is to be in accordance with procedure described in Class Programme DNVGL-CP-0338, Section 4.