DNV·GL

Certificate No:
TAM0000154

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Turbocharger

with type designation(s)
METxxSEII

Issued to
Mitsubishi Heavy Industries Marine Machinery & Equipment Co., Ltd.
Nagasaki City, Nagasaki Pref., Japan

is found to comply with
DNV GL rules for classification – Ships Pt.4 Ch.3 Sec.1 Reciprocating internal combustion engines

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Issued at **Høvik** on **2020-04-03**
This Certificate is valid until **2024-11-11**.
DNV GL local station: **Kobe**

for **DNV GL**

Approval Engineer: **Tage Olav Alexander Strøm**

Oddvar Deinboll
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Product description

Exhaust driven turbochargers served by cylinder groups with combined power in the range from 1300 kW up to 24100 kW

Application/Limitation

Type	MET33SEII		MET42SEII	
Impeller type	2	3	2	3
Impeller tip dia. [mm]		373		462
Max rated speed (RPM)	26960	25440	21760	20540
Max temperature (^{0}C)	580		580	

Type	MET53SEII		MET66SEII	
Impeller size	2	3	2	3
Impeller tip dia. [mm]		586		730
Max rated speed (RPM)	17160	16190	13770	13000
Max temperature (^{0}C)	580		580	

Type	MET71SEII	MET83SEII	
Impeller size	3	2	3
Impeller tip dia. [mm]	790		924
Max rated speed (RPM)	12010	10870	10270
Max temperature (^{0}C)	580		

Type	MET90SE
Impeller size	3
Impeller tip dia. [mm]	1020
Max rated speed (RPM)	9300
Max temperature (^{0}C)	580

Maximum momentary speed is 110% of maximum rated speed.

ALARM LEVELS:
Overspeed, maximum alarm level: 105% of maximum rated speed

High exhaust temperature at turbine entry, maximum alarm level: 550 ºC.

Low lubrication oil pressure at turbocharger inlet, minimum alarm level: 0.6 bar (gauge pressure)

Maximum lubrication oil outlet temperature (alarm level): 85 ºC
Application constraints:

Maximum allowed inclinations for MET turbochargers:
Static: ± 15º
Dynamic (momentary): ± 22.5º

Engine induced vibrations to be within the specified limits given in instruction manuals for MET turbochargers.

Marking of product

The product to be marked with manufacturer's name or trademark and type number identification.

Periodical assessment

For retention of the type approval, a DNV GL surveyor shall perform an assessment after 2 years and after 3.5 years, both referring to the issue date of the type approval certificate to verify that the conditions of the type approval are complied with. A renewal assessment will be performed at renewal of the certificate.

In cases where the type approved product is manufactured at other companies, the periodical assessment shall verify that the type approval applicant has a quality control system for consistent production at their licensees/subcontractors. Furthermore, periodical assessment shall be carried out randomly at these companies.

END OF CERTIFICATE