

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Condenser for Refrigerating Plant**

with type designation(s)

Shell and tube condenser types WXP-111-XS, WXP-111-XST, WXP-112-XST, WXP-112-XS, WXP-113-XS, WXP-142-XS, WXP-143-XS, WXP-144-XS, WXP-142-QS, WXP-143-QS, WXP-142-S, WXP-143-S, WXP-144-S, WXP-161-S, WXP-162-S, WXP-163-S

Issued to

**Hangzhou Safety Equipment Co.,Ltd
Hangzhou 130, China**

is found to comply with

DNV GL rules for classification – Ships Pt.4 Ch.7 Pressure equipment**Application :****Condenser(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Temperature range: +5°C to +55°C****Operating media: R134a, R404a, R407c / water (shell side / tube side)****Design pressure: 28 bar / 10 bar (shell side / tube side)**Issued at **Hamburg** on **2017-02-28**This Certificate is valid until **2022-02-27**.for **DNV GL**DNV GL local station: **Shanghai CMC**Approval Engineer: **Stefan Wiemer**

**Harald Pauli
Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

Shell and tube heat exchanger with flat end plates

Application/Limitation

Applied Rules:

- DNV GL Rules Ship Pt.4 Ch.7 'Pressure Equipment' (Edition January 2017),
- DNV GL Rules Ship Pt.4 Ch.6 Sec.6 'Refrigeration Systems' (Edition January 2017),

Design pressure:	28 bar / 10 bar	(shell side / tube side)
Design temperature:	+5°C +55°C / +5°C + 60°C	(shell side / tube side)
DNV GL Pressure Equipment Class:	II / III	(shell side / tube side)

Materials used shall conform DNVGL Rules Pt.2 Ch.2 Sec.3 and shall be delivered with material certificates according to DNVGL Rules Ship Pt.4 Ch.7 Sec.1 Table 6 and 7,

Manufacturing, workmanship and testing shall be done according to DNV Rules Pt.4 Ch.7 Sec.7, extent of non-destructive testing shall be in line with DNV Rules Pt.4 Ch.7 Sec.7 No. 4.1.2,

Each condenser is to be:

- Hydraulic pressure tested to minimum 1.5 x design pressure,
- Certified by DNV GL and to be delivered with a product certificate when required by DNV GL Rules or by the purchaser.

Type Approval documentation

Marking of product

For traceability to this type approval the products are at least to be marked with:

- the name and domicile of the manufacturer,
- the manufacturer's type designation and serial number,
- the year of manufacture,
- the design pressure,
- the design temperature in °C,
- the hydraulic test pressure, and
- DNV GL's identifying mark

Periodical assessment

The objective of the periodical assessment is to verify that the conditions for the type approval (TA) have not been altered.

The main scope of the periodical assessment will normally include:

- verification of the TA applicant's production and quality system w.r.t. ensuring continued consistent production of the TA products at the TA applicant's own premises and at other companies that are given the responsibility for manufacturing of the products
- review of TA documentation and that this is still used as basis for the production
- review of possible changes in the design, the materials and the performance of the product
- verification of the product marking

For retention of the TA certificate in its validity period the periodical assessments will be carried out bi-yearly.

Unscheduled assessments for retention of the certificate may be carried out when there is reason to believe that the type approval applicant has not adhered to the obligations stipulated in the type approval certificate.

End of Certificate